



**BSR/ASHRAE/IES Addendum bm
to ANSI/ASHRAE/IES Standard 90.1-2016**

Public Review Draft

Proposed Addendum bm to Standard 90.1-2016, Energy Standard for Buildings Except Low-Rise Residential Buildings

**First Public Review (November 2018)
(Draft Shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2018 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 1791 Tullie Circle, NE, Atlanta, GA 30329. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 1791 Tullie Circle, NE, Atlanta GA 30329-2305

© 2018 ASHRAE

This draft is covered under ASHRAE copyright. The appearance of any technical data or editorial material in this publication document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, design or the like and ASHRAE expressly disclaims such. Permission to republish or redistribute must be obtained from the MOS.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This addendum updates table 6.8.1-2 for the following changes;

- 1. Updates the requirements for air cooled >65,000 to >240,000 Btu/h products to show the agreed to Appliance Standards and Rulemaking Federal Advisory Committee (ASRAC) efficiencies that are schedule to go into effect on 1/1/2023. Note that DOE requirements extend to 760,000 Btu/h but table 6.8.1 lumps all very large heat pumps into one category >240,000 Btu/h (rather than specifying separate, less stringent levels for heat pumps >760,000 Btu/h) due to the fact that there are no very large heat pumps produced.*
- 2. Update the air cooled <65,000 Btu/h 3 phase US efficiencies to harmonize with the DOE national efficiencies for single phase. This also includes conversion to the new SEER2 and HSPF2 metric that is defined in the 10 CFR Appendix M1 that goes into effect on 1/1/2023 for single phase product. The effective date for three phase will also be 1/1/2023 and is the same as single phase.*
- 3. Clarified that air cooled <65,000 Btu/h single phase efficiencies outside the US are covered by this table. <65K single phase requirements are regulated as consumer products by DOE and are covered in appendix F*
- 4. With the change to the new SEER2, EER2, and HSPF2 metric there are new test procedures that need to be followed. DOE has defined these in 10 CFR 430 Appendix M1. AHRI is modifying AHRI 210/240 to create a new version called AHRI 210/240-2023 that will be released in January 2019. In the referenced test procedures the requirements are clarified what standard should be used when.*
- 5. Updated to name for thru the wall units to space constrained air cooled and clarified they are for non-US and 3 phase global products. Also updated the efficiency levels to align with DOE requirements defined in appendix F table F-1 for single phase equipment.*
- 6. Updated the small duct high velocity requirements to align with DOE requirements defined in table F-1 and clarified they are for non-US productions and 3 phase global products. Also updated the efficiency levels to align with DOE requirements defined in appendix F table F-1 for single phase equipment.*
- 7. To reduce the complexity of the table and in anticipation of new metrics that will be proposed for water source heat pumps the water source heat pumps requirements have been moved to a new table 6.8.1-17 but with the current efficiency metrics.*
- 8. Changes have also been made to Table F-1 for residential DOE covered products but these will be covered by another addendum.*
- 9. Removed some text at the end of 6.4.1 that is redundant to information already in the footnotes of the tables.*

The economic justification for more stringent efficiency levels for air-cooled <65K single phase and air-cooled 65K to 760K was addressed in the DOE rulemaking documents for the applicable energy conservation standards rulemakings. Note there are no heat pump products above 240K

[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~striketrough~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]

Addendum bm to 90.1-2016

This addendum will revise table 6.8.1-2 and also add also separate water source heat pumps from unitary heat pumps and create a new table 6.8.1-17.

Revised the list of tables in section 6.4.1 and removes text at the bottom the section 6.4.1

6.4.1 Equipment Efficiencies, Verification, and Labeling Requirements

6.4.1.1 Minimum Equipment Efficiencies—Listed Equipment—Standard Rating and Operating Conditions

Equipment shown in Tables 6.8.1-1 through 6.8.1-~~16~~17 shall have a minimum performance at the specified rating conditions when tested in accordance with the specified test procedure. Where multiple rating conditions or performance requirements are provided, the *equipment* shall satisfy all stated requirements unless otherwise exempted by footnotes in the table. *Equipment* covered under the Federal *Energy Policy Act* of 1992 (EPACT) shall have no minimum *efficiency* requirements for operation at minimum capacity or other than standard rating conditions. *Equipment* used to provide *service water-heating* functions as part of a combination *system* shall satisfy all stated requirements for the appropriate *space* heating or cooling category.

Tables are as follows:

- a. Table 6.8.1-1, “Electrically Operated Unitary Air Conditioners and *Condensing Units*—Minimum *Efficiency* Requirements”
- b. Table 6.8.1-2, “Electrically Operated Air Cooled Unitary ~~and Applied~~ Heat Pumps—Minimum *Efficiency* Requirements”
- c. Table 6.8.1-3, “Water-Chilling Packages—*Efficiency* Requirements” (See Section 6.4.1.2 for water-cooled centrifugal water-chilling packages that are designed to operate at nonstandard conditions.)
- d. Table 6.8.1-4, “Electrically Operated *Packaged Terminal Air Conditioners, Packaged Terminal Heat Pumps, Single-Package Vertical Air Conditioners, Single-Package Vertical Heat Pumps, Room Air Conditioners, and Room Air Conditioner Heat Pumps*—Minimum *Efficiency* Requirements”
- e. Table 6.8.1-5, “Warm-Air Furnaces and Combination Warm-Air Furnaces/Air-Conditioning Units, Warm-Air Duct Furnaces, and Unit Heaters—Minimum *Efficiency* Requirements”
- f. Table 6.8.1-6, “Gas- and Oil-Fired *Boilers*—Minimum *Efficiency* Requirements”
- g. Table 6.8.1-7, “Performance Requirements for Heat-Rejection *Equipment*”
- h. Table 6.8.1-8, “Heat Transfer *Equipment*”
- i. Table 6.8.1-9 “Electrically Operated Variable-Refrigerant-Flow Air Conditioners—Minimum *Efficiency* Requirements”
- j. Table 6.8.1-10 “Electrically Operated Variable-Refrigerant-Flow and Applied Heat Pumps—Minimum *Efficiency* Requirements
- k. Table 6.8.1-11, “Air Conditioners and *Condensing Units* Serving *Computer Rooms*”
- l. Table 6.8.1-12, “Commercial Refrigerators and Freezers—Minimum *Efficiency* Requirements”

- m. Table 6.8.1-13, “Commercial Refrigeration—Minimum *Efficiency* Requirements”
- n. Table 6.8.1-14, “Vapor-Compression-Based *Indoor Pool Dehumidifiers*—Minimum *Efficiency* Requirements”
- o. Table 6.8.1-15, “Electrically Operated *DX-DOAS Units*, Single-Package and Remote Condenser, without *Energy Recovery*—Minimum *Efficiency* Requirements”
- p. Table 6.8.1-16, “Electrically Operated *DX-DOAS Units*, Single-Package and Remote Condenser, with *Energy Recovery*—Minimum *Efficiency* Requirements”
- q. Table 6.8.1-17, “Electrically Operated Water Source Heat Pumps—Minimum *Efficiency* Requirements”

~~All furnaces with input ratings of $\leq 225,000$ Btu/h, including electric furnaces that are not located within the conditioned space shall have jacket losses not exceeding 0.75% of the input rating. Air conditioners primarily serving computer rooms and covered by ASHRAE Standard 127 shall meet the requirements in Table 6.8.1-11. All other air conditioners shall meet the requirements in Table 6.8.1-1.~~

Modify the IP standard as follows

Table 6.8.1-2 Electrically Operated Air Cooled Unitary and Applied Heat Pumps—Minimum *Efficiency* Requirements

Equipment Type	Size Category	Heating Section Type	Subcategory or Rating Condition	Minimum Efficiency	Test Procedure ^a
Air cooled (cooling mode)	<65,000 Btu/h ^b	All	Split system, three phase and outside US single phase ^b	14.0 SEER before 1/1/2023 14.3 SEER2 after 1/1/2023	AHRI 210/240-2017 before 1/1/2023
			Single package three phase and outside US single phase ^b	14.0 SEER before 1/1/2023 14.3 SEER2 after 1/1/2023	AHRI 210/240-2023 after 1/1/2023
Through the wall Space Constrained air cooled (cooling mode)	≤30,000 Btu/h ^b	All	Split system, three phase and outside US single phase ^b	12.0 SEER before 1/1/2023 11.7 SEER2 after 1/1/2023	AHRI 210/240-2017 before 1/1/2023
			Single package three phase and outside US single phase ^b	12.0 SEER before 1/1/2023 11.7 SEER2 after 1/1/2023	AHRI 210/240-2023 after 1/1/2023
Small duct, high velocity, air cooled	<65,000 Btu/h ^b	All	Split System, three phase and outside US single phase ^b	44.0-12.0 -SEER before 1/1/2023 12.0 SEER2 After 1/1/2023	AHRI 210/240-2017 before 1/1/2023 AHRI 210/240-2023 after 1/1/2023
Air cooled (cooling mode)	≥65,000 Btu/h and <135,000 Btu/h	Electric resistance (or none)	Split system and single package	11.0 EER 12.2 IEER before 1/1/2023 14.1 IEER after 1/1/2023	AHRI 340/360
		All other		10.8 EER 12.0 IEER before 1/1/2023 13.9 IEER after 1/1/2023	
	≥135,000 Btu/h and <240,000 Btu/h	Electric resistance (or none)	10.6 EER 11.6 IEER before 1/1/2023 13.5 IEER after 1/1/2023		
		All other	10.4 EER 11.4 IEER before 1/1/2023 13.3 IEER after 1/1/2023		
≥240,000 Btu/h	Electric resistance (or none)		9.5 EER 10.6 IEER before 1/1/2023 12.5 IEER after 1/1/2023		

		All other		9.3 <i>EER</i> 10.4 <i>IEER</i> before 1/1/2023 12.3 <i>IEER</i> after 1/1/2023	
Water to air, water loop (cooling mode)	<17,000 Btu/h	All	86°F entering water	12.2 <i>EER</i>	ISO 13256-1
	≥17,000 Btu/h and <65,000 Btu/h			13.0 <i>EER</i>	
	≥65,000 Btu/h and <135,000 Btu/h			13.0 <i>EER</i>	
Water to air, groundwater (cooling mode)	<135,000 Btu/h	All	59°F entering water	18.0 <i>EER</i>	ISO 13256-1
Brine to air, ground loop (cooling mode)	<135,000 Btu/h	All	77°F entering water	14.1 <i>EER</i>	ISO 13256-1
Water to water, water loop (cooling mode)	<135,000 Btu/h	All	86°F entering water	10.6 <i>EER</i>	ISO 13256-2
Water to water, groundwater (cooling mode)	<135,000 Btu/h	All	59°F entering water	16.3 <i>EER</i>	ISO 13256-2
Brine to water, ground loop (cooling mode)	<135,000 Btu/h	All	77°F entering water	12.1 <i>EER</i>	ISO 13256-2
Air cooled (heating mode)	<65,000 Btu/h ^b (cooling capacity)		Split system, three phase and outside US single phase ^b	8.2 <i>HSPF</i> before 1/1/2023 7.5 <i>HSPF2</i> after 1/1/2023	AHRI 210/240-2017 before 1/1/2023
			Single package, three phase and outside US single phase ^b	8.0 <i>HSPF</i> before 1/1/2023 6.7 <i>HSPF2</i> after 1/1/2023	AHRI 210/240-2023 after 1/1/2023
Through the wall Space constrained, air cooled (heating mode)	≤30,000 Btu/h ^b (cooling capacity)		Split system, three phase and outside US single phase ^b	7.4 <i>HSPF</i> before 1/1/2023 6.3 <i>HSPF2</i> after 1/1/2023	AHRI 210/240-2017 before 1/1/2023
			Single package, three phase and outside US single phase ^b	7.4 <i>HSPF</i> before 1/1/2023 6.3 <i>HSPF2</i> after 1/1/2023	AHRI 210/240-2023 after 1/1/2023
Small duct high velocity, air cooled (heating mode)	<65,000 Btu/h ^b		Split system, three phase and outside US single phase ^b	6.8 7.2 <i>HSPF</i> before 1/1/2023 6.1 <i>HSPF2</i> after 1/1/2023	AHRI 210/240-2017 before 1/1/2023 AHRI 210/240-2023 after 1/1/2023
Air cooled (heating mode)	≥65,000 Btu/h ^c and <135,000 Btu/h (cooling capacity)		47°F db/43°F wb outdoor air	3.30 <i>COP_H</i> before 1/1/2023 3.40 <i>COP_H</i> after 1/1/2023	AHRI 340/360
			17°F db/15°F wb outdoor air	2.25 <i>COP_H</i>	
	≥135,000 Btu/h ^c (cooling capacity) and <240,000 Btu/h ^c		47°F db/43°F wb outdoor air	3.20 <i>COP_H</i> before 1/1/2023 3.30 <i>COP_H</i> after 1/1/2023	
			17°F db/15°F wb outdoor air	2.05 <i>COP_H</i>	

	$\geq 240,000$ Btu/h ^c (cooling capacity)		47°F db/43°F wb <i>outdoor air</i>	3.20 COP_H	
			17°F db/15°F wb <i>outdoor air</i>	2.05 COP_H	
Water to air, water loop (heating mode)	$< 135,000$ Btu/h (cooling capacity)		68°F entering water	4.3 COP_H	ISO 13256-1
Water to air, groundwater (heating mode)	$< 135,000$ Btu/h (cooling capacity)		50°F entering water	3.7 COP_H	ISO 13256-1
Brine to air, ground loop (heating mode)	$< 135,000$ Btu/h (cooling capacity)		32°F entering fluid	3.2 COP_H	ISO 13256-1
Water to water, water loop (heating mode)	$< 135,000$ Btu/h (cooling capacity)		68°F entering water	3.7 COP_H	ISO 13256-2
Water to water, groundwater (heating mode)	$< 135,000$ Btu/h (cooling capacity)		50°F entering water	3.1 COP_H	ISO 13256-2
Brine to water, ground loop (heating mode)	$< 135,000$ Btu/h (cooling capacity)		32°F entering fluid	2.5 COP_H	ISO 13256-2

a. Section 12 contains a complete specification of the referenced test procedure, including the referenced year version of the test procedure.

b. Single-phase, air-cooled heat pumps $< 65,000$ Btu/h are regulated as consumer products by the U.S. Department of Energy Code of Federal Regulations 10 CFR 430. SEER, SEER2, and HSPF and HSPF2 values for single-phase products are set by the U.S. Department of Energy.

Informative Note: See Informative [Appendix E](#) for the U.S. Department of Energy minimum.

Move the water source IP heat pumps to a new table 6.8.1-8. Note the efficiency values have not been changed and therefore are not open to comment although they are underlined to indicate they are in a new table.

Table 6.8.1-17 Electrically Operated Water Source Heat Pumps—Minimum Efficiency Requirements

<u>Equipment Type</u>	<u>Size Category</u>	<u>Heating Section Type</u>	<u>Subcategory or Rating Condition</u>	<u>Minimum Efficiency</u>	<u>Test Procedure^a</u>
Water to air, water loop (cooling mode)	<17,000 Btu/h	All	86°F entering water	<u>12.2 EER</u>	ISO 13256-1
	≥17,000 Btu/h and <65,000 Btu/h			<u>13.0 EER</u>	
	≥65,000 Btu/h and <135,000 Btu/h			<u>13.0 EER</u>	
Water to air, groundwater (cooling mode)	<135,000 Btu/h	All	59°F entering water	<u>18.0 EER</u>	ISO 13256-1
Brine to air, ground loop (cooling mode)	<135,000 Btu/h	All	77°F entering water	<u>14.1 EER</u>	ISO 13256-1
Water to water, water loop (cooling mode)	<135,000 Btu/h	All	86°F entering water	<u>10.6 EER</u>	ISO 13256-2
Water to water, groundwater (cooling mode)	<135,000 Btu/h	All	59°F entering water	<u>16.3 EER</u>	ISO 13256-2
Brine to water, ground loop (cooling mode)	<135,000 Btu/h	All	77°F entering water	<u>12.1 EER</u>	ISO 13256-2
Water to air, water loop (heating mode)	<135,000 Btu/h (cooling capacity)		68°F entering water	<u>4.3 COP_H</u>	ISO 13256-1
Water to air, groundwater (heating mode)	<135,000 Btu/h (cooling capacity)		50°F entering water	<u>3.7 COP_H</u>	ISO 13256-1
Brine to air, ground loop (heating mode)	<135,000 Btu/h (cooling capacity)		32°F entering fluid	<u>3.2 COP_H</u>	ISO 13256-1
Water to water, water loop (heating mode)	<135,000 Btu/h (cooling capacity)		68°F entering water	<u>3.7 COP_H</u>	ISO 13256-2
Water to water, groundwater (heating mode)	<135,000 Btu/h (cooling capacity)		50°F entering water	<u>3.1 COP_H</u>	ISO 13256-2
Brine to water, ground loop (heating mode)	<135,000 Btu/h (cooling capacity)		32°F entering fluid	<u>2.5 COP_H</u>	ISO 13256-2

a. Section 12 contains a complete specification of the referenced test procedure, including the referenced year version of the test procedure.

Modify table 6.8.1-2 SI as shown.

Table 6.8.1-2 Electrically Operated Air Cooled Unitary and Applied Heat Pumps—Minimum Efficiency Requirements

<i>Equipment Type</i>	<i>Size Category</i>	<i>Heating Section Type</i>	<i>Subcategory or Rating Condition</i>	<i>Minimum Efficiency</i>	<i>Test Procedure^a</i>
Air cooled (cooling mode)	<19 kW	All	Split system, three phase and outside US single phase ^b	4.10 $SCOP_c$ before 1/1/2023 4.19 $SCOP_{2c}$ after 1/1/2023	AHRI 210/240-2017 before 1/1/2023
			Single package, three phase and outside US single phase ^b	4.10 $SCOP_c$ before 1/1/2023 4.19 $SCOP_{2c}$ after 1/1/2023	AHRI 210/240-2023 After 1/1/2023
Through the wall, air cooled (cooling mode)	≤9 kW	All	Split system, three phase and outside US single phase ^b	3.52 $SCOP_c$ before 1/1/2023 3.42 $SCOP_{2c}$ after 1/1/2023	AHRI 210/240-2017 before 1/1/2023
			Single package, three phase and outside US single phase ^b	3.52 $SCOP_c$ before 1/1/2023 3.42 $SCOP_{2c}$ after 1/1/2023	AHRI 210/240-2023 After 1/1/2023
Small duct, high velocity, air cooled	<19 kW	All	Single package, three phase and outside US single phase ^b	2.93 4.10 $SCOP_c$ before 1/1/2023 4.10 $SCOP_{2c}$ after 1/1/2023	AHRI 210/240-2017 before 1/1/2023 AHRI 210/240-2023 After 1/1/2023
Air cooled (cooling mode)	≥19 kW and <40 kW	Electric resistance (or none)	Split system and single package	3.22 COP_c 3.57 3.58 $ICOP_c$ before 1/1/2023 4.13 $ICOP_c$ before 1/1/2023	AHRI 340/360
		All other		3.17 COP_c 3.52 $ICOP_c$ before 1/1/2023 4.07 $ICOP_c$ after 1/1/2023	
	≥40 kW and <70 kW	Electric resistance (or none)		3.11 COP_c 3.40 $ICOP_c$ before 1/1/2023 3.96 $ICOP_c$ after 1/1/2023	
		All other		3.05 COP_c 3.34 $ICOP_c$ before 1/1/2023 3.90 $ICOP_c$ after 1/1/2023	
≥70 kW	Electric resistance (or none)		2.78 COP_c 3.11 $ICOP_c$ before 1/1/2023 3.66 $ICOP_c$ after 1/1/2023		
	All other		2.72 2.73 COP_c 3.05 $ICOP_c$ before 1/1/2023 3.60 $ICOP_c$ after 1/1/2023		
Water to air, water loop (cooling mode)	<5 kW	All	30°C entering water	3.57 COP_c	ISO 13256-1
	≥5 kW and <19 kW			3.81 COP_c	
	≥19 kW and <40 kW			3.81 COP_c	
Water to air, groundwater (cooling mode)	<40 kW	All	15°C entering water	5.27 COP_c	ISO 13256-1
Brine to air, ground-loop (cooling mode)	<40 kW	All	25°C entering water	4.13 COP_c	ISO 13256-1
Water to water, water loop (cooling mode)	<40 kW	All	30°C entering water	3.10 COP_c	ISO 13256-2

Water to water, groundwater (cooling mode)	<40 kW	All	15°C entering water	4.77 COP _c	ISO 13256-2
Brine to water, ground-loop (cooling mode)	<40 kW	All	25°C entering water	3.55 COP _c	ISO 13256-2
Air cooled (heating mode)	<19 kW ^b (cooling capacity)		Split system, three phase and outside US single phase	2.26-2.40 SCOP _H before 1/1/2023 2.20 SCOP _{2H} after 1/1/2023	AHRI 210/240-2017 before 1/1/2023
			Single Package, three phase and outside US single phase	3.34 2.34 SCOP _H before 1/1/2023 1.96 SCOP _{2H} after 1/1/2023	AHRI 210/240-2023 After 1/1/2023
Through the wall, Space constrained air cooled (heating mode)	≤9 kW ^b (cooling capacity)		Split system, three phase and outside US single phase	2.17 SCOP _H before 1/1/2023 1.83 SCOP _H after 1/1/2023	AHRI 210/240-2017 before 1/1/2023
			Single Package, three phase and outside US single phase	2.17 SCOP _H before 1/1/2023 1.83 SCOP _H after 1/1/2023	AHRI 210/240-2023 After 1/1/2023
Small duct high velocity, air cooled (heating mode)	<19 kW ^b		Single Package, three phase and outside US single phase	2.0 2.11 SCOP _H before 1/1/2023 1.78 SCOP _H after 1/1/2023	AHRI 210/240-2017 before 1/1/2023 AHRI 210/240-2023 After 1/1/2023
Air cooled (heating mode)	≥19 kW and <40 kW (cooling capacity)		8.3°C db/6.1°C wb outdoor air	3.30 COP _H before 1/1/2023 3.40 COP _H after 1/1/2023	AHRI 340/360
			-8.3°C db/-9.4°C wb outdoor air	2.25 COP _H	
	≥40 kW and <70 kW (cooling capacity)		8.3°C db/6.1°C wb outdoor air	3.20 COP _H before 1/1/2023 3.30 COP _H after 1/1/2023	
			8.3°C db/-9.4°C wb outdoor air	2.05 COP _H	
	≥70 kW (cooling capacity)		8.3°C db/6.1°C wb outdoor air	3.20 COP _H	
		8.3°C db/-9.4°C wb outdoor air	2.05 COP _H		
Water to air, water loop (heating mode)	<40 kW (cooling capacity)		20°C entering water	4.3 COP _H	ISO 13256-1
Water to air, groundwater (heating mode)	<40 kW (cooling capacity)		10°C entering water	3.7 COP _H	ISO 13256-1
Brine to air, ground-loop (heating mode)	<40 kW (cooling capacity)		0°C entering fluid	3.2 COP _H	ISO 13256-1
Water to water, water loop (heating mode)	<40 kW (cooling capacity)		20°C entering water	3.7 COP _H	ISO 13256-2
Water to water, groundwater (heating mode)	<40 kW (cooling capacity)		10°C entering water	3.1 COP _H	ISO 13256-2

Brine to water, ground-loop (heating mode)	<40 kW (cooling capacity)	0°C entering fluid	2.5 COP _H	ISO 13256-2
--	---------------------------------	--------------------	----------------------	----------------

- a. Section [12](#) contains a complete specification of the referenced test procedure, including the referenced year version of the test procedure.
- b. Single-phase, US air-cooled heat pumps <19 kW are regulated as consumer products by the U.S. Department of Energy Code of Federal Regulations 10 CFR 430. SCOP_c, SCOP_{2c} and SCOP_H, and SCOP_{2H} values for single-phase products are set by the U.S. Department of Energy.
- Informative Note:** See Informative [Appendix F](#) for the U.S. Department of Energy minimum.

Move the water source SI heat pumps to a new table 6.8.1-8. Note the values have not been changed and therefore are not open to comment although they are underlined to indicate they are in a new table..

Table 6.8.1-17 Electrically Operated Water Source Heat Pumps—Minimum Efficiency Requirements

<u>Equipment Type</u>	<u>Size Category</u>	<u>Heating Section Type</u>	<u>Subcategory or Rating Condition</u>	<u>Minimum Efficiency</u>	<u>Test Procedure^a</u>
<u>Water to air, water loop (cooling mode)</u>	<u><5 kW</u>	<u>All</u>	<u>30°C entering water</u>	<u>3.58 COP_C</u>	ISO 13256-1
	<u>≥5 kW and <19 kW</u>			<u>3.81 COP_C</u>	
	<u>≥19 kW and <40 kW</u>			<u>3.81 COP_C</u>	
<u>Water to air, groundwater (cooling mode)</u>	<u><40 kW</u>	<u>All</u>	<u>15°C entering water</u>	<u>5.28 COP_C</u>	ISO 13256-1
<u>Brine to air, ground loop (cooling mode)</u>	<u><40 kW</u>	<u>All</u>	<u>25°C entering water</u>	<u>4.13 COP_C</u>	ISO 13256-1
<u>Water to water, water loop (cooling mode)</u>	<u><40 kW</u>	<u>All</u>	<u>30°C entering water</u>	<u>3.11 COP_C</u>	ISO 13256-2
<u>Water to water, groundwater (cooling mode)</u>	<u><40 kW</u>	<u>All</u>	<u>15°C entering water</u>	<u>4.78 COP_C</u>	ISO 13256-2
<u>Brine to water, ground loop (cooling mode)</u>	<u><40 kW</u>	<u>All</u>	<u>25°C entering water</u>	<u>3.55 COP_C</u>	ISO 13256-2
<u>Water to air, water loop (heating mode)</u>	<u><40 kW (cooling capacity)</u>		<u>20°C entering water</u>	<u>4.3 COP_H</u>	ISO 13256-1
<u>Water to air, groundwater (heating mode)</u>	<u><40 kW (cooling capacity)</u>		<u>10°C entering water</u>	<u>3.7 COP_H</u>	ISO 13256-1
<u>Brine to air, ground loop (heating mode)</u>	<u><40 kW (cooling capacity)</u>		<u>0°C entering fluid</u>	<u>3.2 COP_H</u>	ISO 13256-1
<u>Water to water, water loop (heating mode)</u>	<u><40 kW (cooling capacity)</u>		<u>20°C entering water</u>	<u>3.7 COP_H</u>	ISO 13256-2
<u>Water to water, groundwater (heating mode)</u>	<u><40 kW (cooling capacity)</u>		<u>10°C entering water</u>	<u>3.1 COP_H</u>	ISO 13256-2
<u>Brine to water, ground loop (heating mode)</u>	<u><40 kW (cooling capacity)</u>		<u>0°C entering fluid</u>	<u>2.5 COP_H</u>	ISO 13256-2

a. Section 12 contains a complete specification of the referenced test procedure, including the referenced year version of the test procedure.