



**BSR/ASHRAE Addendum y
to ANSI/ASHRAE Standard 62.1-2016**

Public Review Draft

Proposed Addendum y to Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality

**Third Public Review (February 2019)
(Draft shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2019 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 1791 Tullie Circle, NE, Atlanta, GA 30329. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 1791 Tullie Circle, NE, Atlanta GA 30329-2305

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Since the original publication of Standard 62.1, ASHRAE published Standard 188-2015 Legionellosis: Risk Management for Building Water Systems. This proposed addendum requires advising the owner of the basic requirements of ASHRAE Standard 188.

[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~striketrough~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]

Addendum y to 62.1-2016

Add new Section 5.18 as follows

5.18 Legionella Risk. The building owner shall be provided with written documentation of the design information for all of the HVAC-related water systems and elements that are required to be addressed by ANSI/ASHRAE Standard 188^X.

Informative Note: Typical elements of the HVAC system addressed by Standard 188 include: open- and closed-circuit cooling towers and evaporative condensers that provide cooling or refrigeration for the HVAC system and humidification systems. This requirement is related to HVAC's influence on Legionnaires' Disease risk, but it is important to note that there are multiple sources of potential water-to-people transmission inside buildings that are potable water based, such as shower heads, some humidifiers, and ice machines, as well as non-potable sources that are not associated with HVAC, such as decorative water features.

Add a new reference to Section 9 as shown below. The remainder of Section 9 is unchanged.

9. References

X. ANSI/ASHRAE Standard 188-2018, Legionellosis: Risk Management for Building Water Systems. Atlanta: ASHRAE.