



**BSR/ASHRAE Addendum ac
to ANSI/ASHRAE Standard 62.1-2016**

Public Review Draft

Proposed Addendum ac to Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality

**Third Public Review (March 2019)
(Draft shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research-technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2019 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 1791 Tullie Circle, NE, Atlanta, GA 30329. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 1791 Tullie Circle, NE, Atlanta GA 30329-2305

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Informative Appendix C (Summary of Selected Air Quality Guidelines) in 62.1-2016 was deleted in a previous addendum. This proposed addendum adds a new Informative Appendix C with content supportive of changes to the Indoor Air Quality Procedure (IAQP).

[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~strikethrough~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]

Addendum ac to 62.1-2016

Add a new Informative Appendix C as shown below. Re-letter existing appendices as appropriate.

(This appendix is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

INFORMATIVE APPENDIX C

C1. SUMMARY OF SELECTED AIR QUALITY GUIDELINES

If the IAQ Procedure is used, acceptable indoor concentrations limits are needed for design compounds and particles. When using this procedure, these concentration limits need to be documented and justified by reference to a cognizant authority as defined in the standard. At present, no single organization develops acceptable concentrations limits for all substances in indoor air, nor are limits available for all potential design compounds or particles.

Cognizant authorities, such as USEPA, California EPA, and the Committee for Health Related Evaluation of Building Products (AgBB) publish concentration limits for compounds, many of which may be present in the indoor environment. Compounds included in the IAQP design need to be included if data were judged sufficient to indicate a compound was likely to be found in buildings at concentrations that were a substantial fraction of the proposed Design Target (DT). The goal is not to include every possible compound that may appear in indoor air, but sufficient numbers of compounds and diversity thereof such that control of the compounds is anticipated to result in air quality that meets the standard's definition of "acceptable."

A summary of considerations is presented below:

1. Is a compound expected to be present in indoor air with reasonable frequency at concentrations relevant to (but not necessarily above) the Design Target? Specifically, the design zone outdoor air flow rate (Voz) and design features will be controlled by the compounds with the highest emission rates and lowest targets (taking

mixtures into account); thus, compounds with low concentrations and high targets will have little or no impact on the calculated V_{oz} .

2. Is there a Design Target that has been proposed by a cognizant authority?
3. Does it seem reasonable to expect that product emissions rates may be available for the proposed compound?
4. Is there an established sampling and analytical method for the proposed compound?

Occupational exposure limits (e.g., Permissible Exposure Limits and Threshold Limit Values) are not appropriate as Design Targets, as they are not established for acceptable indoor air quality or for typical commercial buildings. In general, they were developed for industrial applications evaluating effects of substances on healthy adult male workers.

C2. GUIDELINE FOR EMISSION RATES

Several published peer-reviewed papers provide a reference for design teams to use to compile reasonable Design Compound (DC) emission rates. A non-exhaustive list of peer-reviewed papers is shown in the references. In addition, there are multiple established certification programs that include empirical measures of emission rates for construction materials as well as finishes, furniture and equipment intended for indoor use. These include 3rd party programs as well as industry trade association programs and programs in support of government regulations (e.g. the AgBB evaluation scheme used in Germany and parts of Europe, also Blue Angel, BIFMA, Green Label, France A+, CDPH Standard Method for testing and evaluation of VOC emissions). Engineers may use the emission rates for the specific materials that a designer is including or considering for use. The IAQP (Section 6.3) requires that emission rates must consider DCs emitted by occupants and their activities, by materials, by specific sources within the occupied spaces, and introduced into the building with outside air.

C3. SUBJECTIVE EVALUATION

Section 6.3.4.2 requires that an occupant survey be conducted. Many subjective evaluation approaches have been used with varying degrees of success. The following is an example of an evaluation approach which focuses on adapted occupants. 1) After the building is completed and substantially occupied, provide all occupants with an electronic or written set of survey questions, including: “Do you perceive the air quality in your environment to be acceptable or unacceptable? 2) Anonymous surveys with neutrally-framed questions provide the best responses. 3) When conducting an evaluation of adapted occupants, respondents must record their ~~opinion~~ of perception of zone air quality after 30 minutes residency in the occupied zone. 4) All occupants should be surveyed, if possible. Otherwise, at least 50% of typical occupancy, or 300, whichever is less, should be randomly selected. 5) A minimum of a 30% response rate from those surveyed is desirable. Each zone must be surveyed per requirements of section 6.3. The subjective evaluation validates the acceptability of indoor air if 80% of respondents in the area do not express dissatisfaction. The Center for the Built Environment at UC Berkeley has developed a survey including IAQ questions which may be a useful template.

C4. REFERENCES

- Aggazzotti G, Fantuzzi G, Righi E, Predieri G. Blood and breath analyses as biological indicators of exposure to trihalomethanes in indoor swimming pools. The Science of the total environment. 1998;217(1-2):155-63.
- Ahn JH, Szulejko JE, Kim KH, Kim YH, Kim BW. Odor and VOC emissions from pan frying of mackerel at three stages: Raw, well-done, and charred. Int J Environ Res Public Health. 2014;11(11):11753-71.
- Alevantis LE, Levin H, Miller R, Waldman JM, Mudarri D, editors. Lessons learned from product testing, source Evaluation, and air sampling from a five-building sustainable office complex. Healthy Buildings: 2006; Lisbon, Portugal.
- Apte MG. Final Report Balancing energy conservation and occupant needs in ventilation rate standards for Big Box stores in California: predicted indoor air quality and energy consumption using a matrix of

ventilation scenarios. Lawrence Berkeley National Laboratory, 2013 LBNL Paper LBNL-5551E Contract No.: LBNL Paper LBNL-5551E.

- Assadi AA, Palau J, Bouzaza A, Penya-Roja J, Martinez-Soriac V, Wolbert D. Abatement of 3-methylbutanal and trimethylamine with combined plasma and photocatalysis in a continuous planar reactor. J Photochem Photobiol A-Chem. 2014;282:1-8.
- Atkinson R, Tuazon EC, Arey J, Aschmann SM. Atmospheric and indoor chemistry of gas-phase indole, quinoline, and isoquinoline. Atmospheric Environment. 1995;29(23):3423-32.
- Barro R, Regueiro J, Llompарт M, Garcia-Jares C. Analysis of industrial contaminants in indoor air: part 1. Volatile organic compounds, carbonyl compounds, polycyclic aromatic hydrocarbons and polychlorinated biphenyls. Journal of chromatography A. 2009;1216(3):540-66.
- Bartlett KH, Kennedy SM, Brauer M, van Netten C, Dill B. Evaluation and determinants of airborne bacterial concentrations in school classrooms. J Occup Environ Hyg. 2004;1(10):639-47.
- Batterman S, Su FC, Li S, Mukherjee B, Jia C. Personal exposure to mixtures of volatile organic compounds: modeling and further analysis of the RIOPA data. Research report (Health Effects Institute). 2014(181):3-63.
- Bi XH, Sheng GY, Feng YL, Fu JM, Xie JX. Gas- and particulate-phase specific tracer and toxic organic compounds in environmental tobacco smoke. Chemosphere. 2005;61(10):1512-22.
- Boraphech P, Thiravetyan P. Removal of trimethylamine (fishy odor) by C-3 and CAM plants. Environ Sci Pollut Res. 2015;22(15):11543-57.
- Bradman A, Gaspar F, Castorina R, Williams J, Hoang T, Jenkins PL, et al. Supporting Information: Formaldehyde and acetaldehyde exposure and risk characterization in california early childhood education environments. Indoor Air. 2016.
- Brown SK, Sim MR, Abramson MJ, Gray CN. Concentrations of volatile organic compounds in indoor air - A review. Indoor Air. 1994;4:123-34.
- Chan WR, Cohn S, Sidheswaran M, Sullivan DP, Fisk WJ. Contaminant levels, source strengths, and ventilation rates in California retail stores. Indoor Air. 2015;25(4):381-92.
- Choo CP, Jalaludin J. An overview of indoor air quality and its impact on respiratory health among Malaysian school-aged children. Reviews on environmental health. 2015;30(1):9-18.
- Claeson AS, Sandstrom M, Sunesson AL. Volatile organic compounds (VOCs) emitted from materials collected from buildings affected by microorganisms. J Environ Monit. 2007;9(3):240-5.
- Cometto-Muniz JE, Abraham MH. Compilation and analysis of types and concentrations of airborne chemicals measured in various indoor and outdoor human environments. Chemosphere. 2015;127:70-86.
- Cometto-Muniz JE, Cain WS. Sensory irritation. Relation to indoor air pollution. Annals of the New York Academy of Sciences. 1992;641:137-51.
- Cooper SD, Raymer JH, Pellizzari ED, Thomas KW. The identification of polar organic compounds found in consumer products and their toxicological properties. Journal of exposure analysis and environmental epidemiology. 1995;5(1):57-75.
- CDPH, Long-Term Building Air Measurements For Volatile Organic Compounds Including Aldehydes At A California Five-Building Sustainable Office Complex, volume (1/2 and 2/2), 2006.
- Daisey JM. Tracers for assessing exposure to environmental tobacco smoke: what are they tracing? Environmental health perspectives. 1999;107 Suppl 2:319-27.
- Daisey JM, Hodgson AT, Fisk WJ, Mendell MJ, Ten Brinke J. Volatile organic compounds in twelve California office buildings: Classes, concentrations and sources. Atmospheric Environment. 1994;28(22):3557-62.
- Dodson RE, Levy JI, Houseman EA, Spengler JD, Bennett DH. Evaluating methods for predicting indoor residential volatile organic compound concentration distributions. Journal of Exposure Science & Environmental Epidemiology. 2009;19(7):682-93.
- Dutton SM. Evaluation of the indoor air quality procedure for use in retail buildings. Lawrence Berkeley National Laboratory, 2014 LBNL Paper LBNL-6079E Contract No.: LBNL Paper LBNL-6079E.
- Fenske JD, Paulson SE. Human breath emissions of VOCs. J Air Waste Manage Assoc. 1999;49(5):594-8.

- Fischer ML, Littlejohn D, Lunden MM, Brown NJ. Automated measurements of ammonia and nitric acid in indoor and outdoor air. *Environmental Science & Technology*. 2003;37(10):2114-9.
- Girman JR. Volatile organic compounds and building bake-out. *Occupational medicine (Philadelphia, Pa)*. 1989;4(4):695-712.
- Godwin C, Batterman S. Indoor air quality in Michigan schools. *Indoor Air*. 2007;17(2):109-21.
- Harrison RM, Delgado-Saborit JM, Baker SJ, Aquilina N, Meddings C, Harrad S, et al. Measurement and modeling of exposure to selected air toxics for health effects studies and verification by biomarkers. Research report (Health Effects Institute). 2009(143):3-96; discussion 7-100.
- Hau KM, Connell DW, Richardson BJ. Use of partition models in setting health guidelines for volatile organic compounds. *Regulatory toxicology and pharmacology : RTP*. 2000;31(1):22-9.
- Hau KM, Connell DW, Richardson BJ. Use of partition models to evaluate guidelines for mixtures of volatile organic compounds. *Regulatory toxicology and pharmacology : RTP*. 2000;32(1):36-41.
- Hodgson AT, Daisey JM, Grot RA. Sources and source strengths of volatile organic compounds in a new office building. *J Air Waste Manage Assoc*. 1991;41(11):1461-8.
- Hodgson AT, Faulkner D, Sullivan DP, DiBartolomeo DL, Russell ML, Fisk WJ. Effect of outside air ventilation rate on VOC concentrations and emissions in a call center. LBL, 2002 Contract No.: 49535.
- Hodgson AT, Levin H. Volatile organic compounds in indoor air: A review of concentrations measured in North America since 1990. Berkeley, CA: E.O. Lawrence Berkely National Laboratory, 2003 Oct. 2003. Report No.: LBNL-51715 Contract No.: LBNL-51715.
- Hotchi T, Hodgson AT, Fisk WJ. Indoor air quality impacts of a peak load shedding strategy for a large retail building. LBL, 2006 Contract No.: 500-03-026, PIER Demand Response Research Center.
- Ilacqua V, Hänninen O, Kuenzli N, Jantunen MF. Intake fraction distributions for indoor VOC sources in five European cities. *Indoor Air*. 2007;17(5):372-83.
- Kinney PL, Chillrud SN, Ramstrom S, Ross J, Spengler JD. Exposures to multiple air toxics in New York City. *Environmental health perspectives*. 2002;110:539-46.
- Kristiansen A, Saunders AM, Hansen AA, Nielsen PH, Nielsen JL. Community structure of bacteria and fungi in aerosols of a pig confinement building. *FEMS Microbiol Ecol*. 2012;80(2):390-401.
- Lamorena RB, Lee W. Influence of ozone concentration and temperature on ultra-fine particle and gaseous volatile organic compound formations generated during the ozone-initiated reactions with emitted terpenes from a car air freshener. *J Hazard Mater*. 2008;158(2-3):471-7.
- Lee SC, Lam S, Fai HK. Characterization of VOCs, ozone, and PM10 emissions from office equipment in an environmental chamber. *Build Environ*. 2001;36(7):837-42.
- Leovic KW, Sheldon LS, Whitaker DA, Hetes RG, Calcagni JA, Baskir JN. Measurement of indoor air emissions from dry-process photocopy machines. *J Air Waste Manage Assoc*. 1996;46(9):821-9.
- Levin H. Building materials and indoor air quality. *Occupational medicine (Philadelphia, Pa)*. 1989;4(4):667-93.
- Lindgren T. A case of indoor air pollution of ammonia emitted from concrete in a newly built office in Beijing. *Build Environ*. 2010;45(3):596-600.
- Lioy PJ, Fan Z, Zhang J, Georgopoulos P, Wang SW, Ohman-Strickland P, et al. Personal and ambient exposures to air toxics in Camden, New Jersey. Research report (Health Effects Institute). 2011(160):3-127; discussion 9-51.
- Liu W, Zhang J, Zhang L, Turpin BJ, Weisel CP, Morandi MT, et al. Estimating contributions of indoor and outdoor sources to indoor carbonyl concentrations in three urban areas of the United States. *Atmospheric Environment*. 2006;40(12):2202-14.
- Mikkola R, Andersson MA, Hautaniemi M, Salkinoja-Salonen MS. Toxic indole alkaloids avrainvillamide and stephacidin B produced by a biocide tolerant indoor mold *Aspergillus westerdijkiae*. *Toxicon*. 2015;99:58-67.
- Nagda NL, Rector HE. A critical review of reported air concentrations of organic compounds in aircraft cabins. *Indoor Air*. 2003;13(3):292-301.
- Nazaroff WW, Weschler CJ. Cleaning products and air fresheners: exposure to primary and secondary air pollutants. *Atmospheric Environment*. 2004;38(18):2841-65.

- [Nielsen GD, Hansen LF, Nexo BA, Poulsen OM. Indoor air guideline levels for formic, acetic, propionic and butyric acid. Indoor Air-Int J Indoor Air Qual Clim. 1998;8-24.](#)
- [Nirlo E. Assessing and controlling concentrations of volatile organic compounds: The University of Texas Austin; 2014.](#)
- [Norback D, Wieslander G. Biomarkers and chemosensory irritations. International archives of occupational and environmental health. 2002;75\(5\):298-304.](#)
- [Ohura T, Amagai T, Shen X, Li S, Zhang P, Zhu L. Comparative study on indoor air quality in Japan and China: Characteristics of residential indoor and outdoor VOCs. Atmospheric Environment. 2009;43\(40\):6352-9.](#)
- [Oikawa D, Takeuchi W, Murata S, Takahashi K, Sekine Y. Measurement of concentrations of thioglycolic acid, dithiodiglycolic acid and ammonia in indoor air of a beauty salon. J Occup Health. 2012;54\(5\):370-5.](#)
- [Pant P, Guttikunda SK, Peltier RE. Exposure to particulate matter in India: A synthesis of findings and future directions. Environmental Research. 2016;147:480-96.](#)
- [Park JS, Ikeda K. Variations of formaldehyde and VOC levels during 3 years in new and older homes. Indoor Air. 2006;16\(2\):129-35.](#)
- [Repace JL, Hyde JN, Brugge D. Air pollution in Boston bars before and after a smoking ban. BMC public health. 2006;6:266.](#)
- [Risner CH, Conner JM. Collection of ammonia in indoor air by means of a weak cation-exchange cartridge. Environ Toxicol Chem. 1991;10\(11\):1417-23.](#)
- [Roberts JW, Dickey P. Exposure of children to pollutants in house dust and indoor air. Reviews of environmental contamination and toxicology. 1995;143:59-78.](#)
- [Roda C, Kousignian I, Guihenneuc-Jouyaux C, Dassonville C, Nicolis I, Just J, et al. Formaldehyde exposure and lower respiratory infections in infants: Findings from the PARIS cohort study. Environmental health perspectives. 2011;119\(11\):1653-8.](#)
- [Rohr AC. The health significance of gas- and particle-phase terpene oxidation products: a review. Environment international. 2013;60:145-62.](#)
- [Saha CK, Zhang GQ, Kai P, Bjerg B. Effects of a partial pit ventilation system on indoor air quality and ammonia emission from a fattening pig room. Biosyst Eng. 2010;105\(3\):279-87.](#)
- [Salonen HJ, Pasanen AL, Lappalainen SK, Riuttala HM, Tuomi TM, Pasanen PO, et al. Airborne concentrations of volatile organic compounds, formaldehyde and ammonia in Finnish office buildings with suspected indoor air problems. J Occup Environ Hyg. 2009;6\(3\):200-9.](#)
- [Santarsiero A, Fuselli S, Piermattei A, Morlino R, De Blasio G, De Felice M, et al. Investigation of indoor air volatile organic compounds concentration levels in dental settings and some related methodological issues. Annali dell'Istituto superiore di sanita. 2009;45\(1\):87-98.](#)
- [Sarigiannis DA, Karakitsios SP, Gotti A, Liakos IL, Katsoyiannis A. Exposure to major volatile organic compounds and carbonyls in European indoor environments and associated health risk. Environment international. 2011;37\(4\):743-65.](#)
- [Sax SN, Bennett DH, Chillrud SN, Kinney PL, Spengler JD. Differences in source emission rates of volatile organic compounds in inner-city residences of New York City and Los Angeles. Journal of Exposure Analysis & Environmental Epidemiology. 2004;14:S95-S109.](#)
- [Schripp T, Langer S, Salthammer T. Interaction of ozone with wooden building products, treated wood samples and exotic wood species. Atmospheric Environment. 2012;54:365-72.](#)
- [Shah JJ, Singh HB. Distribution of volatile organic chemicals in outdoor and indoor air: A national VOCs data base. Environ Sci Technol. 1988;22\(12\):1381-8.](#)
- [Siegel JA, Srebric J, Crain N, Nirlo E, Zaatari M, Hoisington A, et al. Ventilation and Indoor Air Quality in Retail Stores.pdf>. ASHRAE, 2012 Contract No.: RP-1596.](#)
- [Smith TJ, Davis ME, Hart JE, Blicharz A, Laden F, Garshick E. Potential air toxics hot spots in truck terminals and cabs. Research report \(Health Effects Institute\). 2012\(172\):5-82.](#)
- [Tham KW, Zuraimi MS, Sekhar SC. Emission modelling and validation of VOCs' source strengths in air-conditioned office premises. Environment international. 2004;30\(8\):1075-88.](#)

- Vainiotalo S, Vaananen V, Vaaranrinta R. Measurement of 16 volatile organic compounds in restaurant air contaminated with environmental tobacco smoke. Environmental Research. 2008;108(3):280-8.
- Wang S, Ang HM, Tade MO. Volatile organic compounds in indoor environment and photocatalytic oxidation: state of the art. Environment international. 2007;33(5):694-705.
- Wang TC. A study of bioeffluents in a college classroom. ASHRAE transactions. 1975;81(1):1-12.
- Weisel CP. Assessing exposure to air toxics relative to asthma. Environmental health perspectives. 2002;110 Suppl 4:527-37.
- Winkle MR, Scheff PA. Volatile organic compounds, polycyclic aromatic hydrocarbons and elements in the air of ten urban homes. Indoor Air. 2001;11(1):49-64.
- Wolkoff P. Indoor air pollutants in office environments: assessment of comfort, health, and performance. International journal of hygiene and environmental health. 2013;216(4):371-94.
- Wolkoff P, Wilkins CK, Clausen PA, Nielsen GD. Organic compounds in office environments - sensory irritation, odor, measurements and the role of reactive chemistry. Indoor Air. 2006;16(1):7-19.
- Wu XM, Apte MG, Maddalena R, Bennett DH. Volatile organic compounds in small- and medium-sized commercial buildings in California. Environ Sci Technol. 2011;45(20):9075-83.
- Wu XM, Apte MG, Maddalena R, Bennett DH. Appendix Volatile organic Compounds (VOCs) in small and medium sized commercial buildings in California. Environ Sci Technol. 2011;45(20).
- Zaatari M, Siegel J. Particle characterization in retail environments: concentrations, sources, and removal mechanisms. Indoor Air. 2014;24(4):350-61.
- Zhu J, Newhook R, Marro L, Chan CC. Selected Volatile Organic Compounds in Residential Air in the City of Ottawa, Canada. Environmental Science & Technology. 2005;39(11):3964-71.