



**BSR/ASHRAE Addendum ai
to ANSI/ASHRAE Standard 62.1-2016**

Public Review Draft

Proposed Addendum ai to Standard 62.1-2016, Ventilation for Acceptable Indoor Air Quality

**First Public Review (February 2019)
(Draft shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2019 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 1791 Tullie Circle, NE, Atlanta, GA 30329. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 1791 Tullie Circle, NE, Atlanta GA 30329-2305

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This proposed addendum removes language published in Addendum q to Standard 62.1-2016. It reinstates the option of using indirect measurement techniques in testing and balancing (TAB) of the ventilation system in startup.

[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~striketrough~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]

Addendum ai to 62.1-2016

Modify Section 7.2.2 as shown below. See published Addendum q to 62.1-2016 posted for free download on the ASHRAE website at <https://www.ashrae.org/technical-resources/standards-and-guidelines/standards-addenda>.

7.2.2 Air Balancing and Verification of Outdoor Air Performance. Ventilation systems shall be balanced in accordance with ASHRAE Standard 111¹⁵ or other applicable national standards, so as to verify conformance with the total outdoor airflow requirements of this standard (V_{ot}). ~~Conformance shall be confirmed by direct measurement at the minimum design airflow rate (or rates) during normal operation.~~