



**BSR/ASHRAE Addendum v  
to ANSI/ASHRAE Standard 62.2-2016**

**Public Review Draft**

# **Proposed Addendum v to Standard 62.2-2016, Ventilation and Acceptable Indoor Air Quality in Residential Buildings**

**Second Public Review (July 2019)  
(Draft Shows Proposed **Independent Substantive  
Changes** to Previous Public Review Draft)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at [www.ashrae.org/standards-research--technology/public-review-drafts](http://www.ashrae.org/standards-research--technology/public-review-drafts) and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at [www.ashrae.org/bookstore](http://www.ashrae.org/bookstore) or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, [www.ashrae.org](http://www.ashrae.org).

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2019 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 1791 Tullie Circle, NE, Atlanta, GA 30329. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: [standards.section@ashrae.org](mailto:standards.section@ashrae.org).

**ASHRAE, 1791 Tullie Circle, NE, Atlanta GA 30329-2305**

**(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)**

## FOREWORD

*This proposed addendum updates the normative references in Section 9 (References) of Standard 62.2.*

*[Note to Reviewers: This public review draft makes proposed independent substantive changes to the previous public review draft. These changes are indicated in the text by underlining (for additions) and ~~strikethrough~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the previous draft are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed substantive changes.]*

## Addendum v to 62.2-2016

---

***Make the following changes to Section 6.9.***

**6.9 Carbon Monoxide Alarms.** A carbon monoxide alarm shall be installed in each dwelling unit in accordance with NFPA 720, *National Fire Alarm and Signaling Code* ~~Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment~~<sup>14</sup>, and shall be consistent with requirements of applicable laws, codes, and standards.

***Make the following changes to the references in Section 9. The remainder of the references in Section 9 are unchanged.***

## 9. REFERENCES

14. ~~NFPA 720-2015, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment~~ *NFPA 72-2019, National Fire Alarm and Signaling Code*. National Fire Protection Association, Quincy, MA.