



**BSR/ASHRAE Addendum d
to ANSI/ASHRAE Standard 15-2019**

Public Review Draft

Proposed Addendum d to Standard 15-2019, Safety Standard for Refrigeration Systems

**First Public Review (May 2020)
(Draft shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2020 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 1791 Tullie Circle, NE, Atlanta, GA 30329. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 1791 Tullie Circle, NE, Atlanta GA 30329-2305

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

*This addendum revises the scope of the standard to clarify that it does not apply to residential refrigeration systems covered by ASHRAE Standard 15.2P. **This change in scope will not be effective until the publication of ASHRAE Standard 15.2P.***

Note: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~strike through~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.

Addendum d to Standard 15-2019

Modify Section 2 as follows. The remainder of Section 2 remains unchanged.

2. SCOPE

- 2.1** This standard establishes safeguards for life, limb, health, and property and prescribes safety requirements.
- 2.2** This standard applies to:
 - a. the design, construction, test, installation, operation and inspection of mechanical and absorption refrigeration systems, including heat pump systems used in stationary applications;
 - b. modifications including replacement of parts or components if they are not identical in function and capacity; and
 - c. substitutions of refrigerant having a different designation.
- 2.3** This standard does not apply to refrigeration systems using ammonia (R-717) as the refrigerant.
- 2.4** This standard does not apply to residential refrigeration systems serving only a single dwelling unit or sleeping unit complying with ASHRAE Standard 15.2.