



**BSR/ASHRAE Addendum o
to ANSI/ASHRAE Standard 62.1-2022**

Public Review Draft

Proposed Addendum o to Standard 62.1-2022, Ventilation and Acceptable Indoor Air Quality

**First Public Review (February 2024)
(Draft shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2024 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 180 Technology Parkway, Peachtree Corners, Georgia 30092. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 180 Technology Parkway, Peachtree Corners, Georgia 30092

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Proposed Addendum o adds additional documentation recommendations to Informative Appendix I for the edition of the standard used in design, the rating of filters and air cleaners, and the date of the last air balancing. The inclusion of this information will improve awareness of operators of the design conditions of their ventilation systems.

[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~strikes through~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]

Addendum o to 62.1-2022

Modify Informative Appendix I as shown below. The remainder of Informative Appendix I is unchanged.

Building Ventilation Design Criteria							
Designed according to ASHRAE Standard 62.1-[year of Standard]							
Total Building Outdoor Air Intake	Total Building Exhaust Air (see Section 5.17)	Outdoor Air Cleaning Required (See Section 6.1.4)			Indoor Air Dew Point (Section 5.12)		Air Balancing (See Sections 5.10.3 and 7.2.2) and Date Last Performed
		Particulate Matter	Ozone	Filter / Air Cleaner Rating and Location	Peak Outdoor DP at Dehumidification Design Condition	Calculated Space DP at Concurrent Outdoor Condition	
(cfm)	(cfm)	(Yes/No)	(Yes/No)	(MERV or ISO rating, upstream of coil)	(Dew point)	(Dew point)	(NEBB, AABC, etc., January 1, 2022)