



**BSR/ASHRAE Addendum a to
ANSI/ASHRAE Guideline 28-2016**

Public Review Draft

Proposed Addendum a to Guideline 28-2016, Air Quality within Commercial Aircraft

**Second Public Review (November 2018)
(Draft shows Proposed Changes to Current Guideline)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed guideline, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the guideline (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any guideline may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This guideline is under continuous maintenance. To propose a change to the current guideline, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2018 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 1791 Tullie Circle, NE, Atlanta, GA 30329. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 1791 Tullie Circle, NE, Atlanta GA 30329-2305

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

The purpose of this addendum is to clarify the test criteria for HEPA filters in Section 8.1.2.4 (Respirable Particulate Matter) and to add/update the relevant references in Section 9 (References).

Note: In this addendum, changes to the current guideline are indicated in the text by underlining (for additions) and ~~strikethrough~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum a to Guideline 28-2016

Revise Section 8.1.2.4 (Respirable Particulate Matter) as shown below.

8.1.2.4 Respirable Particulate Matter (RPM). Respirable particulate matter consists of solid or liquid particles that, with diameters less than 10 μm , are easily suspended in air and inhaled by exposed persons. RPM on aircraft can be generated from a variety of sources. The relative contribution of different sources to RPM on aircraft is currently not known. A major source of RPM is the airplane occupants. Pollutants generated by occupants are distinct from other types of particle sources in that the emissions occur where an individual is located and the occupant is not always stationary, but rather can move around. Occupants can generate RPM that may contain viruses or bacteria that are suspended in mucus generated from coughing or sneezing and that are found in organic and inorganic compounds carried by larger particles such as skin flakes or clothing fiber. Another source of RPM on airplanes is accumulated dust, which is resuspended in the air by occupants as they move around the aircraft cabin. This dust could contain allergenic material such as endotoxins and mycotoxins, as well as other irritating and potentially toxic chemicals such as pesticides. Other sources of RPM include galley operations, episodic introduction of fluids such as fuel and oil via the ventilation system, spraying of pesticides and cleaners, and equipment operation. Fleecy materials (e.g., carpet, seating) can be sources of RPM as a result of occupant movement (SAE 2006a).

Particle diameter, chemical composition, airborne concentrations, duration of exposure to RPM, and individual sensitivity all play a part in the impact particles have on aircraft occupants. A recent study showed that during normal operations, the highest concentrations of particulate matter were present during boarding and deplaning (Dumyahn et al. 2000). At the same time, a number of studies, including ASHRAE Research Projects 957 (RP-957) (Pierce et al. 1999) and 959 (RP-959) (Nagda et al. 2001) have shown that mass concentrations of particles during cruise are very low during normal conditions, often in the range of 10 $\mu\text{g}/\text{m}^3$. In a typical aircraft ventilation system, air that is recirculated is usually passed through high efficiency high efficiency particulate air arresting (HEPA) filters: ~~removing particles with great efficiency. HEPA filters that meet or exceed the requirements for Filter Type "A," as defined by Institute of Environmental Science and Technology IEST-RP-CC001.6 (IEST, 2016), 7.21 is, Class H13 be tested according to EN1822-1 (CEN, 2009), or ISO35H according to ISO 29463 (ISO, 2011). efficiency rating is provide a minimum of 99.977% collection efficiency for 0.3 μm particles as defined by Institute of Environmental Science and Technology (IEST, 2016). Alternatively, the filters shall meet or exceed the requirements for filter class H13 to EN1822 (CEN, 2009) and shall provide a minimum of 99.95% overall collection efficiency at the most penetrating particle size. Outside air typically passes through the~~

~~system without filtration but is no of concern as a source of particles since there are very few particles at altitude.~~ The U.S. Environmental Protection Agency (EPA) has developed National Ambient Air Quality Standards (NAAQS) for PM_{2.5} (particulate matter with aerodynamic diameter <2.5 µm). PM_{2.5} is not regulated by the federal aviation regulations (FARs). They are included in this guideline because PM_{2.5} has been documented to cause adverse chronic health effects upon exposure and because particles in this size range have the ability to penetrate into the deepest areas of the human lung upon inhalation. The NAAQS maximums for PM_{2.5} are 15 µg/m³ annual arithmetic mean (three-year average) and 65 µg/m³ over 24 hours (three-year average of the 98th percentile of 24-hour concentrations). Canadian Exposure Guidelines place a limit of <100 µg/m³ for a one-hour interval for particles having <2.5 µm mass median aerodynamic diameter.

The U.S. EPA has also developed NAAQS for PM₁₀ (particulate matter with aerodynamic diameter <10 µm). PM₁₀ is not regulated by the FARs. They are included in this guideline because of their irritancy potential, although they are large enough that they will not penetrate to the deepest areas of the human lung when inhaled. The NAAQS for PM₁₀ are 50 µg/m³ annual arithmetic mean and 150 µg/m³ over 24 hours.

To meet the NAAQS for PM_{2.5} and PM₁₀, particulate matter is collected on filter media using certified air-sampling instrumentation and gravimetrically analyzed. The EPA recommends gravimetric determination of mass concentrations by collecting particulate matter on filters using certified air-sampling instrumentation since NAAQS are based on health effects studies that predominantly used gravimetric methods to characterize particular matter. In addition to mass concentrations, particle diameter and number concentrations are also very important parameters for describing airborne particulate matter. Particle deposition in the lungs upon inhalation is a strong function of particle size. Optical-laser particle counters (OPCs) are commonly used instruments that count the number of particles in sampled air as a function of particle diameter and time. However, very few of the health standards are based on characterization of particulate matter using optical particle counters. Typically, OPCs measure particles in the size range 0.1 to >10 µm, depending on the instrument and how it is calibrated. Particles smaller than 0.1 µm diameter are typically referred to as ultrafine particulate matter. Ultrafine particles are currently measured using condensation particles counters (CPC), which increase the diameter of the particle by using it as condensation nuclei until it is large enough to be detected optically by a laser. CPCs only provide total number of particles as a function of time and do not provide any sizing information. To size particles smaller than 0.1 µm, a CPC is usually coupled to an electrostatic classifier, which uses electrostatic forces to separate the particles according to size (Baron and Willeke 2001). Aerodynamic sizing instruments are also in common use. These instruments allow real-time measurement of aerodynamic diameter based on acceleration and time-of-flight principles (Baron and Willeke 2001). Typically, these instruments can measure particle diameters from about 0.5 to 100 µm.

Revise Section 9 as shown below. The rest of Section 9 remains unchanged.

9. REFERENCES

CEN. 2009. EN1822: *High Efficiency Air Filters (EPA, HEPA and ULPA) - Part 1: Classification, Performance Testing Markings*. Brussels, Belgium: European Committee for Standardization.

IEST. 2016. IEST-RP-CC001.6: *HEPA and ULPA Filters*, 6th Edition. Mt. Prospect, IL. Institute of Environmental Science and Technology.

ISO (2011) “High-efficiency filters and filter media for removing particles in air — Part 1: Classification, performance testing and marking,” ISO 29463-1: 2011(E), First Edition. International Organization for Standardization, Geneva, Switzerland, 2011.