



**BSR/ASHRAE/IES Addendum f
to ANSI/ASHRAE/IES Standard 90.1-2019**

Public Review Draft

Proposed Addendum f to Standard 90.1-2019, Energy Standard for Buildings Except Low-Rise Residential Buildings

**Second ISC Public Review (July 2020)
(Draft Shows Proposed Independent Substantive
Changes to Previous Public Review Draft)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2020 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 1791 Tullie Circle, NE, Atlanta, GA 30329. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 1791 Tullie Circle, NE, Atlanta GA 30329-2305

© 2020 ASHRAE

This draft is covered under ASHRAE copyright. The appearance of any technical data or editorial material in this publication document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, design or the like and ASHRAE expressly disclaims such. Permission to republish or redistribute must be obtained from the MOS.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This ISC is being prepared to correct an error in the original 1st public review document. Only the changes made by this ISC are shown in strike-out and underline text.

The following is the foreword from the first public review.

Historically, the required efficiency increases to eliminate economizer has been a point of confusion for the industry. The confusion stems from whether you need to increase both the full load efficiency and part load efficiency or just the part load efficiency of the equipment. Additionally, if the metric is not in the format of work out divided by energy in (ex. IPLV), then you could get different efficiency levels required based on how you do the math. This change should address both issues. (Note: the values in the table are not underlined and not up for public review/comment.). The language was also changed to allow for a broader range of rating metrics that are being utilized in different rating standards.

The ISC corrects a mistake found during review by the Mechanical Subcommittee. The instruction to multiply by the efficiency value in Table 6.5.1-2

There is no cost impact to this revision as it just clarifies the use of the standard.

[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~striketrough~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]

Addendum f to 90.1-2019

Modify the standard as follows (IP Units)

Table 6.5.1-2 Eliminate Required Economizer for Comfort Cooling by Increasing Cooling Efficiency

Climate Zone	Efficiency Improvement^a
2A	17%
2B	21%
3A	27%
3B	32%
3C	65%
4A	42%
4B	49%
4C	64%
5A	49%
5B	59%
5C	74%
6A	56%
6B	65%
7	72%
8	77%

- a. If a unit is rated with an annualized or part-load metric, then to eliminate the required economizer, only the annualized or part-load minimum cooling efficiency of the unit must be increased by the percentage shown. If the unit is only rated with a full-load metric like EER cooling, then these must be increased by the percentage shown. To determine the efficiency required to eliminate the economizer, when the unit *equipment efficiency* is rated with an energy-input divided by work-output metric, the metric shall first be converted to COP and then the COP shall be increased ~~prior to multiplying~~ by the *efficiency* improvement percentage shown. ~~The COP shall and then be converted back to the original rated metric to establish the efficiency required to eliminate the economizer.~~

Informative note: Some examples of annualized or part-load metrics are: IPLV, IP, IEER, and SEER.

No changes are made to the SI requirements in the ISC. There were changes in the 1st public review which can be seen in the reference sections below.

Note to Reviewers: The following is the final version of the addendum as it would appear with the 1st full public review and 2nd ISC public review combined. It is provided for reference only:

Modify the standard as follows (IP Units)

Table 6.5.1-2 Eliminate Required Economizer for Comfort Cooling by Increasing Cooling Efficiency

Climate Zone	Efficiency Improvement ^a
2A	17%
2B	21%
3A	27%
3B	32%
3C	65%
4A	42%
4B	49%
4C	64%
5A	49%
5B	59%
5C	74%
6A	56%
6B	65%
7	72%
8	77%

- a. If a unit is rated with an annualized or part-load metric IPLV, IEER, or SEER, then to eliminate the required economizer, only the annualized or part-load minimum cooling efficiency of the HVAC unit must be increased by the percentage shown. If the HVAC unit is only rated with a full-load metric like EER cooling, then these must be increased by the percentage shown. To determine the efficiency required to eliminate the economizer when the unit equipment efficiency is rated with an energy-input divided by work-output metric, the metric shall first be converted to COP by the efficiency improvement percentage shown. The COP shall then be converted back to the original rated metric to establish the efficiency required to eliminate the economizer.

Informative note: Some examples of annualized or part-load metrics are: IPLV, IP, IEER, and SEER.

Modify the standard as follows (SI Units)

Table same as I-P version

- a. If a unit is rated with an annualized or part-load metric IPLV, ICOP, or SEER, then to eliminate the required economizer, only the annualized or part-load minimum cooling efficiency of the HVAC unit must be increased by the percentage shown. If the HVAC unit is only rated with a full-load metric like COP cooling, then these must be increased by the percentage shown.

Informative note: Some examples of annualized or part-load metrics are: IPLV, SI, ISCO_{P,C}, and SCOP_C.