



**BSR/ASHRAE Addendum *k* to
ANSI/ASHRAE Standard 154-2016**

Public Review Draft

Proposed Addendum *k* to Standard 154-2016, Ventilation for Commercial Cooking Operations

**First Public Review (September 2021)
(Draft shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research-technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

©2021 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 180 Technology Parkway, Peachtree Corners, GA 30092. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 180 Technology Parkway, Peachtree Corners GA 30092

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Addendum K makes changes to Section 5.5.3 to reflect the latest listing requirement for pollution control units (PCUs) for commercial cooking applications and harmonizes this requirement with IMC 2021, Section 506.5.2. Also, UL 8782 is added to the reference section.

5.5.3 Pollution control units equipped or not equipped with electrostatic precipitators shall be listed in accordance with UL8782, ~~the applicable requirements of UL710⁵ and UL1978⁸. Pollution control units equipped with electrostatic precipitators shall be listed in accordance with UL867¹⁷ and the applicable requirements of UL710⁵ and UL1978⁸.~~

Add to Section 9 References

19. UL. 2017 Issue Number 1, UL 8782, *Outline of Investigation for Pollution Control Units for Commercial Cooking Operations*, Northbrook, IL: Underwriters Laboratories, Inc.