



**BSR/ASHRAE/ASHE Addendum c
to ANSI/ASHRAE/ASHE Standard 189.3-2021**

Public Review Draft

**Proposed Addendum c to
Standard 189.3-2021, Design,
Construction, and Operation of
Sustainable High-Performance
Health Care Facilities**

**First Public Review (April 2022)
(Draft shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2022 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 180 Technology Parkway NW, Peachtree Corners, GA 30092. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 180 Technology Parkway NW, Peachtree Corners, GA 30092

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Addendum ax to ANSI/ASHRAE/ICC/USGBC/IES Standard 189.1-2020 adds a reference to ANSI/ASHRAE Standard 62.1, Section 7, “Construction and System Start-Up,” which includes several requirements that support good indoor air quality. To avoid duplication and confusion, it also deletes some requirements from Standard 189.1, Section 10, that are covered by the referenced section in Standard 62.1.

Standard 189.3, Section 10.2, “Compliance,” notes the “construction and plans for operation shall comply with provisions of Standard 189.1, Section 10, except as specifically deleted, excepted, modified, or enhanced in accordance with Sections 10.3 through 10.5 of this standard. This proposed addendum to Standard 189.3 eliminates Standard 189.1 Addendum ax from being incorporated into Standard 189.3 and provides alternative requirements for IAQ Construction Management and Start-up by referenced section in ANSI/ASHRAE/ASHE Standard 170.

Note: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~strike through~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.

Addendum c to Standard 189.3-2021

Add new Section 10.4 as shown.

10.4 Construction

10.4.1 IAQ Construction Management and System Startup. Ventilation systems shall be constructed and started in compliance with ANSI/ASHRAE/ASHE Standard 170, Section 10.