

BSR/ASHRAE/IES Addendum bi to ANSI/ASHRAE/IES Standard 90.1-2022

Public Review Draft

Proposed Addendum bi to

Standard 90.1-2022, Energy Standard

for Sites and Buildings Except Low-

Rise Residential Buildings

First Public Review (December 2024) (Draft Shows Proposed Changes to Current Standard)

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at <u>www.ashrae.org/standards-research--technology/public-review-drafts</u> and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at <u>www.ashrae.org/bookstore</u> or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, <u>www.ashrae.org</u>.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2024 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 180 Technology Parkway NW, Peachtree Corners, GA 30092. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: <u>standards.section@ashrae.org</u>.

ASHRAE, 180 Technology Parkway NW, Peachtree Corners, GA 30092

BSR/ASHRAE/IES Addendum bi to ANSI/ASHRAE/IES Standard 90.1-2022, Energy Standard for Sites and Buildings Except Low-Rise Residential Buildings First Public Review Draft

© 2024 ASHRAE

This draft is covered under ASHRAE copyright. The appearance of any technical data or editorial material in this publication document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, design or the like and ASHRAE expressly disclaims such. Permission to republish or redistribute must be obtained from the MOS.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

The modification changes the metric from energy cost to site energy use when determining compliance with the Appendix G Performance Rating Method. Use of site energy as the metric better supports ASHRAE and SSPC goals of net zero operational energy emission buildings.

This addendum to the standard is designed to provide increased flexibility and therefore was not subjected to cost effectiveness analysis.

[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by <u>underlining</u> (for additions) and strikethrough (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]

Addendum bi to 90.1-2022

Revise Section 3.1 as follows:

baseline building performance: the annual *energy* cost <u>site energy</u> use for a *building* design intended for use as a baseline for rating above-standard design or when using the *Performance Rating Method* as an alternative path for minimum standard compliance in accordance with Section 4.2.1.1.

proposed building performance: the annual energy cost site energy use calculated for a proposed design.

Revise Section 4 as follows:

4.2 Compliance

4.2.1 Compliance Paths

4.2.1.1 New Buildings. New buildings shall comply with Section 4.2.2 through 4.2.5 and either the pro- visions of

- a. Sections 5, "Building Envelope"; 6, "Heating, Ventilating, and Air Conditioning"; 7, "Service Water Heating"; 8, "Power"; 9, "Lighting"; 10, "Other Equipment"; and 11, "Additional Efficiency Requirements," or
- b. Section 12, "Energy Cost Budget Method," or
- c. Normative Appendix G, "Performance Rating Method."

When using Normative Appendix G, the Performance Cost Index (PCI) of for new buildings, additions to existing buildings, and/or alterations to buildings, the following

BSR/ASHRAE/IES Addendum bi to ANSI/ASHRAE/IES Standard 90.1-2022, Energy Standard for Sites and Buildings Except Low-Rise Residential Buildings First Public Review Draft

<u>requirements</u> shall be <u>met less than or equal to the Performance Cost Index Target (PCI_t) when</u> calculated in accordance with the following:

The Site Performance Energy Index (PEI_{site}) shall be less than or equal to the Site Performance Energy Index Target (PEI_{site}) calculated in accordance with this Section. Site energy shall be determined using the site energy conversion factors provided in Table 4.2.1-2. Conversion factors for energy sources not included in Table 4.2.1-2 shall be approved by the rating authority.

The Site Performance Energy Index Target (PEI_{site.t}) is calculated as follows:

 $PCEI_{site,t} = [BBUECU + (BPF x BBRECU) - PRE] / BBP$

where

<u>PCE</u> I <u>site,t</u>	=	Site Performance Cost Energy Index Target calculated in accordance with Section G1.2.2
BBUE C U	=	<i>baseline building <u>design</u></i> unregulated <u>site energy cost use</u> , the portion of the annual <u>site energy cost</u> use of a <i>baseline building design</i> that is due to <i>unregulated</i> energy use
BPF	=	<i>building</i> performance factor from Table 4.2.1.1. For <i>building</i> area types not listed in Table 4.2.1.1, use "All others." Where a <i>building</i> has multiple <i>building</i> area types, the required BPF shall be equal to the area-weighted average of the <i>building</i> area types based on their gross floor area. Where a project includes an <i>existing building</i> and an <i>addition</i> , the required BPF shall be equal to the area- weighted average, based on the gross floor area, of the <i>existing building</i> BPF determined as described in Section 4.2.1.3 and the <i>addition</i> BPF from Table 4.2.1.1.
BBRE C U	=	baseline <i>building <u>design</u></i> regulated <u>site energy</u> cost <u>use</u> , the portion of the annual <u>site energy</u> cost <u>use</u> of a <i>baseline building design</i> that is due to <i>regulated energy use</i>
PRE	=	PBP _{nre} – PBP _{pre}
PBP	=	<i>proposed building performance</i> , including the reduced, annual <i>purchased</i> <i>energy</i> cost <u>use</u> associated with all <i>on-site renewable energy</i> generation <i>systems</i>
PBP _{nre}	=	proposed building performance without any credit for reduced annual energy costs use from on-site renewable energy generation systems
PBP _{pre}	=	proposed building performance, excluding any renewable energy system in the proposed design and including an on-site renewable energy system that meets but does not exceed the requirements of Section 10.5.1.1 modeled following the requirements for a budget building design in Table 12.5.1, row 15
BBP	=	baseline building performance

Regulated *energy* cost shall be calculated by multiplying the total *energy* cost by the ratio of *regulated energy use* to total *energy* use for each *fuel* type. Unregulated *energy* cost shall be calculated by subtracting regulated *energy* cost from total *energy* cost.

When $(PBP_{pre} - PBP)/BBP > 0.05$, new *buildings*, *additions* to *existing buildings*, and/or *alterations* to *existing buildings* shall comply with the following:

PCEI_{site} + [(PBP_{pre} - PBP)/BBP] - 0.05
$$\leq$$
 PCEI_{site},

BSR/ASHRAE/IES Addendum bi to ANSI/ASHRAE/IES Standard 90.1-2022, Energy Standard for Sites and Buildings Except Low-Rise Residential Buildings First Public Review Draft

Informative Notes:

- 1. PBP_{nre} = proposed building performance, no renewable energy.
- 2. PBP_{pre} = proposed building performance, prescriptive renewable energy.
- 3. PRE = prescriptive renewable *energy*.
- 4. See Informative Appendix I for using other metrics, including *site energy*, source *energy*, and carbon emissions, in conjunction with the Normative Appendix G *Performance Rating Method* when approved by the *rating authority*.

Ruilding	Climate Zone																		
Area Type	0A	0B	1A	1B	2A	2B	3A	3B	3C	4A	4 B	4 C	5A	5B	5C	6A	6B	7	8
Multifamily	0.69	0.68	0.71	0.70	0.72	0.72	0.71	0.76	0.63	0.69	0.76	0.71	0.66	0.72	0.71	0.65	0.67	0.65	0.67
Healthcare/hospital	0.69	0.69	0.70	0.68	0.67	0.65	0.65	0.66	0.64	0.64	0.66	0.63	0.67	0.65	0.65	0.66	0.67	0.68	0.70
Hotel/motel	0.66	0.66	0.69	0.65	0.65	0.64	0.64	0.65	0.65	0.63	0.65	0.63	0.62	0.63	0.62	0.61	0.62	0.59	0.58
Office	0.54	0.5 4	0.53	0.52	0.52	0.52	0.50	0.5 4	0.48	0.48	0.53	0.48	0.49	0.52	0.48	0.48	0.49	0.46	0.48
Restaurant	0.62	0.59	0.57	0.57	0.57	0.53	0.57	0.53	0.51	0.55	0.5 4	0.54	0.57	0.56	0.55	0.59	0.58	0.61	0.64
Retail	0.51	0.49	0.48	0.48	0.4 4	0.43	0.43	0.43	0.44	0.42	0.43	0.46	0.43	0.42	0.47	0.43	0.43	0.41	0.44
School	0.52	0.57	0.57	0.56	0.52	0.53	0.52	0.49	0.50	0.46	0.47	0.47	0.47	0.46	0.46	0.46	0.44	0.45	0.45
Warehouse	0.26	0.26	0.22	0.25	0.21	0.22	0.25	0.21	0.19	0.25	0.22	0.22	0.28	0.2 4	0.22	0.31	0.28	0.29	0.32
All-others	0.62	0.60	0.62	0.59	0.55	0.51	0.53	0.52	0.55	0.53	0.52	0.55	0.53	0.53	0.56	0.5 4	0.54	0.5 4	0.5 4

Table 4.2.1.1 Building Performance Factor (BPF)

Building		<u>Climate Zone</u>																	
<u>Area Type</u>	<u>0A</u>	<u>0B</u>	<u>1A</u>	<u>1B</u>	<u>2A</u>	<u>2B</u>	<u>3A</u>	<u>3B</u>	<u>3C</u>	<u>4A</u>	<u>4B</u>	<u>4C</u>	<u>5A</u>	<u>5B</u>	<u>5C</u>	<u>6A</u>	<u>6B</u>	<u>7</u>	<u>8</u>
Multifamily	<u>0.72</u>	<u>0.71</u>	<u>0.75</u>	<u>0.73</u>	<u>0.76</u>	<u>0.76</u>	<u>0.77</u>	<u>0.75</u>	<u>0.70</u>	<u>0.61</u>	<u>0.71</u>	<u>0.64</u>	<u>0.56</u>	<u>0.63</u>	<u>0.63</u>	<u>0.54</u>	<u>0.57</u>	<u>0.54</u>	<u>0.56</u>
Healthcare/hospital	<u>0.67</u>	<u>0.66</u>	<u>0.68</u>	<u>0.65</u>	<u>0.65</u>	<u>0.61</u>	<u>0.62</u>	<u>0.64</u>	<u>0.63</u>	<u>0.62</u>	<u>0.63</u>	<u>0.61</u>	<u>0.65</u>	<u>0.63</u>	<u>0.68</u>	<u>0.64</u>	<u>0.68</u>	<u>0.69</u>	<u>0.71</u>
Hotel/motel	<u>0.69</u>	<u>0.69</u>	<u>0.72</u>	<u>0.68</u>	<u>0.69</u>	<u>0.68</u>	<u>0.69</u>	<u>0.70</u>	<u>0.71</u>	<u>0.65</u>	<u>0.69</u>	<u>0.68</u>	<u>0.63</u>	<u>0.66</u>	<u>0.67</u>	<u>0.60</u>	<u>0.64</u>	<u>0.59</u>	<u>0.58</u>
Office	<u>0.54</u>	<u>0.54</u>	<u>0.53</u>	<u>0.52</u>	<u>0.52</u>	<u>0.52</u>	<u>0.50</u>	<u>0.54</u>	<u>0.47</u>	<u>0.47</u>	<u>0.52</u>	<u>0.48</u>	<u>0.49</u>	<u>0.52</u>	<u>0.49</u>	<u>0.48</u>	<u>0.50</u>	<u>0.43</u>	<u>0.46</u>
Restaurant	<u>0.64</u>	<u>0.61</u>	<u>0.60</u>	<u>0.59</u>	<u>0.60</u>	<u>0.57</u>	<u>0.61</u>	<u>0.62</u>	<u>0.61</u>	<u>0.66</u>	<u>0.65</u>	<u>0.66</u>	<u>0.69</u>	<u>0.69</u>	<u>0.68</u>	<u>0.71</u>	<u>0.71</u>	<u>0.72</u>	<u>0.74</u>
Retail	<u>0.51</u>	<u>0.49</u>	<u>0.48</u>	<u>0.48</u>	<u>0.44</u>	<u>0.43</u>	<u>0.43</u>	<u>0.44</u>	<u>0.44</u>	<u>0.47</u>	<u>0.45</u>	<u>0.50</u>	<u>0.52</u>	<u>0.47</u>	<u>0.52</u>	<u>0.52</u>	<u>0.50</u>	<u>0.48</u>	<u>0.49</u>
School	<u>0.52</u>	<u>0.57</u>	<u>0.57</u>	<u>0.56</u>	<u>0.52</u>	<u>0.53</u>	<u>0.53</u>	<u>0.52</u>	<u>0.55</u>	<u>0.42</u>	<u>0.49</u>	<u>0.53</u>	<u>0.44</u>	<u>0.50</u>	<u>0.51</u>	<u>0.43</u>	<u>0.42</u>	<u>0.42</u>	<u>0.44</u>
Warehouse	<u>0.26</u>	<u>0.26</u>	<u>0.22</u>	<u>0.25</u>	<u>0.21</u>	0.22	<u>0.25</u>	0.21	<u>0.18</u>	<u>0.38</u>	0.27	<u>0.31</u>	<u>0.46</u>	<u>0.37</u>	<u>0.31</u>	<u>0.49</u>	<u>0.42</u>	<u>0.43</u>	<u>0.47</u>
All others	<u>0.63</u>	<u>0.62</u>	<u>0.65</u>	<u>0.61</u>	<u>0.56</u>	<u>0.53</u>	<u>0.55</u>	<u>0.55</u>	<u>0.59</u>	<u>0.55</u>	<u>0.55</u>	<u>0.58</u>	<u>0.57</u>	<u>0.57</u>	<u>0.61</u>	<u>0.57</u>	<u>0.57</u>	<u>0.56</u>	<u>0.58</u>

Table 4.2.1-2 Site Energy Conversion Factors

Building Project Energy Source	<u>Units</u>	<u>Site energy Btu/unit</u>					
Electricity	kWh	3,412					
Natural Gas	Therm	100,000					
Propane	Therm	<u>100,000</u>					
Distillate fuel oil	Gallon	137,600					
District Chilled Water	Ton	12,000					
District Steam*	Pound	1,150					
District Hot Water	Therm	100,000					

*Saturated steam at 1 atmosphere (14.696 psia)

BSR/ASHRAE/IES Addendum bi to ANSI/ASHRAE/IES Standard 90.1-2022, Energy Standard for Sites and Buildings Except Low-Rise Residential Buildings First Public Review Draft

For the Appendix G revisions that follow, note that revisions to Section G2.4.2 were previously proposed in Addendum ar, which has not yet been published. The changes proposed here are intended to supersede the current standard as well the language previously introduced in Addendum ar.

Normative Appendix G Performance Rating Method

G1.2.2 Performance Rating Calculation. The performance of the *proposed design* is calculated in accordance with provisions of this appendix using the following formula:

<u>Site</u> Performance <u>Cost-Energy</u> Index = *Proposed building performance*/*Baseline building performance*

Both the *proposed building performance* and the *baseline building performance* shall include all end-use load components within and associated with the *property* when calculating the <u>Performance Cost IndexSite</u> <u>Performance Energy Index</u>.

Exception to G1.2.2: Energy used to recharge or refuel vehicles that are used for off-*site* transportation purposes shall not be modeled in the *baseline building performance* or the *proposed building performance*.

Informative Notes:

- Neither the proposed building performance nor the baseline building performance are predictions of actual energy consumption or costs for the proposed design after construction. Actual experience will differ from these calculations due to variations such as occupancy, building operation and maintenance, weather, energy use not covered by this procedure, changes in energy rates between design of the building and occupancy, and the precision of the calculation tool.
- 2. See Informative Appendix I for using other metrics, including site *energy*, source *energy*, and carbon emissions, in conjunction with the Normative Appendix G *Performance Rating Method* when approved by the *rating authority*.

•••

G1.3.2 Application Documentation. The following documentation shall be submitted to the *rating authority:*

a. The *simulation program* used, the version of the *simulation program*, and the results of the *energy* analysis, including the calculated values for baseline *building* unregulated *energy* eost <u>use</u> (BBUEC<u>U</u>), baseline *building* regulated *energy* eost <u>use</u> (BBREC<u>U</u>), *building* performance factor (BPF), *baseline building performance*, the *proposed building performance*, <u>Site Performance Cost</u> Energy Index (PCEI_{site.f}).

••

n. Purchased energy rates used in the simulations.

o. <u>n.</u> An explanation of any error messages noted in the *simulation program* output. ...

G2.4 Renewable, and Recovered, and Purchased Energy.

G2.4.1 On-Site Renewable Energy and Site-Recovered Energy. *Site-recovered energy* shall not be considered *purchased energy* and shall be subtracted from the *proposed design energy* consumption prior to calculating the *proposed building performance. On-site renewable energy* shall be subtracted from the *proposed design energy* consumption prior to calculating the *proposed building performance*, provided that the *building owner*

- a. owns the on-site renewable energy system or
- b. has signed a lease agreement for the on-site renewable energy system for at least 15 years or
- c. has signed a contractual agreement to purchase energy generated by the on-site renewable energy system

BSR/ASHRAE/IES Addendum bi to ANSI/ASHRAE/IES Standard 90.1-2022, Energy Standard for Sites and Buildings Except Low-Rise Residential Buildings First Public Review Draft

for at least 15 years.

G2.4.2 Annual Energy Costs. On-Site Electricity Generation Systems. The design energy cost and baseline energy cost shall be determined using either actual rates for purchased energy or state average energy prices published by U.S. DOE's Energy Information Administration (EIA) for commercial building customers, but rates from different sources may not be mixed in the same project. Where on site renewable energy or site recovered energy is used, the baseline building design shall be based on the energy source used as the backup energy source, or the baseline system energy source in that category if no backup energy source has been specified, except where the baseline energy source is prescribed in Tables G3.1.1 2 and G3.1.1 3. Where the proposed design includes onsite electricity generation systems other than on-site renewable energy systems, the baseline design shall include the same generation systems excluding its site-recovered energy.

Informative Note: The above provision allows users to gain credit for features that yield load management benefits. Where such features are not present, users can simply use state average unit prices from EIA, which are updated annually and readily available on EIA's website (www.eia.gov).

G2.5 Exceptional Calculation Methods. When the *simulation program* does not model design, material, or device of the *proposed design*, an exceptional calculation method shall be used as approved by the *rating authority*. Where there are multiple designs, materials, or devices that the *simulation program* does not model, each shall be calculated separately and exceptional savings determined for each. At no time shall the total exceptional savings constitute more than half of the difference between the *baseline building performance* and the *proposed building performance*. All applications for approval of an exceptional method shall include the following:

- a. Theoretical and empirical information verifying the method's accuracy, and step-by-step documentation of the exceptional calculation method performed, detailed enough to reproduce the results.
- b. Copies of all spreadsheets used to perform the calculations.
- c. A sensitivity analysis of energy consumption when each of the input parameters that are estimated is varied
- d. from half to double the value assumed.
- e. The calculations shall be performed on a time-step basis consistent with the *simulation program* used.
- f. The Site Performance Cost Index calculated with and without the exceptional calculation method.