



**BSR/ASHRAE/IES Addendum by  
to ANSI/ASHRAE/IES Standard 90.1-2022**

**Public Review Draft**

# **Proposed Addendum by to Standard 90.1-2022, Energy Standard for Sites and Buildings Except Low- Rise Residential Buildings**

**First Public Review (Jan 2025)  
(Draft Shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at [www.ashrae.org/standards-research--technology/public-review-drafts](http://www.ashrae.org/standards-research--technology/public-review-drafts) and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at [www.ashrae.org/bookstore](http://www.ashrae.org/bookstore) or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, [www.ashrae.org](http://www.ashrae.org).

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2024 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 180 Technology Parkway NW, Peachtree Corners, GA 30092. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: [standards.section@ashrae.org](mailto:standards.section@ashrae.org).

**ASHRAE, 180 Technology Parkway NW, Peachtree Corners, GA 30092**

© 2024 ASHRAE

***This draft is covered under ASHRAE copyright. The appearance of any technical data or editorial material in this publication document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, design or the like and ASHRAE expressly disclaims such. Permission to republish or redistribute must be obtained from the MOS.***

**(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)**

## FOREWORD

*Section 12 Energy Cost Budget includes equations to remove the fan power from the hypothetical baseline mechanical system. New efficiency metrics were introduced in the Section 6 mechanical equipment tables where SEER and HSPF values were updated to SEER2 and HSPF2 values.*

*These equations apply to baseline systems 3, 4, 9, and 11 when the systems are under 65,000 btu/h. The Department of Energy issued EERE–2014–BT–STD– 0048 which identifies the translation of SEER to SEER2 and HSPF to HSPF2 equivalency. The single package AC and HP had a SEER of 14 with a new rating of SEER2 of 13.4. The single package heat pump HSPF went from 8.0 to an HSPF2 of 6.7. Lacking further industry data, this proposal uses the ratio of the old to new metrics to update the equations:*

### **Original Equations (IP):**

$$COP_{nfcooling} = -0.0076 \times SEER^2 + 0.3796 \times SEER$$

$$COP_{nfheating} = -0.0296 \times HSPF^2 + 0.7134 \times HSPF$$

### **New Equations (IP):**

$$\begin{aligned} COP_{nfcooling} &= -0.0076 \times (14/13.4*SEER2)^2 + 0.3796 \times (14/13.4*SEER2) \\ &= -0.0083 \times SEER2^2 + 0.3966 \times SEER2 \end{aligned}$$

$$\begin{aligned} COP_{nfheating} &= -0.0296 \times (8/6.7*HSPF2)^2 + 0.7134 \times (8/6.7*HSPF2) \\ &= -0.0422 \times HSPF2^2 + 0.8518 \times HSPF2 \end{aligned}$$

### **Original Equations (SI):**

$$\begin{aligned} COP_{nfcooling} &= -0.0885 \times SCOP_C^2 + 1.295 \times SCOP_C \\ COP_{nfheating} &= -0.3446 \times SCOP_H^2 + 2.434 \times SCOP_H \end{aligned}$$

### **New Equations (SI):**

$$\begin{aligned} COP_{nfcooling} &= -0.0885 \times (4.1/3.93*SCOP_{2C})^2 + 1.295 \times (4.1/3.93*SCOP_{2C}) \\ &= -0.0963 \times SCOP_{2C}^2 + 1.351 \times SCOP_{2C} \end{aligned}$$

$$\begin{aligned} COP_{nfheating} &= -0.3446 \times (2.34/1.96*SCOP_H)^2 + 2.434 \times (2.34/1.96*SCOP_H) \\ &= -0.4912 \times SCOP_{2H}^2 + 2.906 \times SCOP_{2H} \end{aligned}$$

*[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~strikethrough~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]*

## Addendum bv to 90.1-2022

---

### 12.5 Calculation of Design Energy Cost and Energy Cost Budget

#### 12.5.2 HVAC Systems.

- c. **Supply Fan Energy in Certain Package Equipment.** Where *efficiency* ratings include supply fan energy, the *efficiency* rating shall be adjusted to remove the supply fan energy. For budget system Types 3, 4, 6, 8, 9, 10, and 11, calculate the minimum  $COP_{nfcooling}$  and  $COP_{nfheating}$  using the equation for the applicable performance rating as indicated in Tables 6.8.1-1, 6.8.1-2, 6.8.1-4, and 6.8.1-15. Where a full- and part-load *efficiency* rating is provided in Tables 6.8.1-1, 6.8.1-2, 6.8.1-4, and 6.8.1-15, the full-load equation below shall be used:

(IP)

$$COP_{nfcooling} = 7.84E-8 \times EER \times Q + 0.338 \times EER$$

~~$$COP_{nfcooling} = -0.0076 \times SEER^2 + 0.3796 \times SEER$$~~

~~$$COP_{nfcooling} = -0.0083 \times SEER^2 + 0.3966 \times SEER$$~~

(applies to cooling *efficiency* only)

$$COP_{nfheating} = 1.48E-7 \times COP_{47} \times Q + 1.062 \times COP_{47}$$

(applies to Systems 6 and 9 heating *efficiency* only)

~~$$COP_{nfheating} = -0.0296 \times HSPF^2 + 0.7134 \times HSPF$$~~

~~$$COP_{nfheating} = -0.0422 \times HSPF^2 + 0.8518 \times HSPF$$~~

$$COP_{nfcooling} = 0.3322 \times EER - 0.2145$$

(applies to Systems 8 and 10 cooling *efficiency* only)

$$COP_{nfheating} = 1.1329 \times COP - 0.214 \text{ (applies to System 8 heating } *efficiency* \text{ only)}$$

(SI)

$$COP_{nfcooling} = 9.13E-4 \times COP_C \times Q + 1.15 \times COP_C$$

~~$$COP_{nfcooling} = -0.0885 \times SCOP_C^2 + 1.295 \times SCOP_C$$~~

~~$$COP_{nfcooling} = -0.0963 \times SCOP_C^2 + 1.351 \times SCOP_C$$~~

(applies to cooling *efficiency* only)

$$COP_{nfheating} = 5.05E-4 \times COP_{H8.3} \times Q + 1.062 \times COP_{H8.3}$$

(applies to Systems 6 and 9 heating *efficiency* only)

~~$$COP_{nfheating} = -0.3446 \times SCOP_H^2 + 2.434 \times SCOP_H$$~~

~~$$COP_{nfheating} = -0.4912 \times SCOP_H^2 + 2.906 \times SCOP_H$$~~

$$COP_{nfcooling} = 1.1338 \times COP - 0.2145$$

(applies to Systems 8 and 10 cooling *efficiency* only)

$$COP_{nfheating} = 1.1329 \times COP - 0.214$$

(applies to System 8 heating *efficiency* only)