



**BSR/ASHRAE/IES Addendum ba
to ANSI/ASHRAE/IES Standard 90.1-2022**

Public Review Draft

Proposed Addendum ba to Standard 90.1-2022, Energy Standard for Sites and Buildings Except Low- Rise Residential Buildings

**Second Public Review (March 2025)
(Draft Shows Proposed Independent Substantive Changes
to Previous Public Review Draft)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2025 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 180 Technology Parkway NW, Peachtree Corners, GA 30092. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 180 Technology Parkway NW, Peachtree Corners, GA 30092

© 2025 ASHRAE

This draft is covered under ASHRAE copyright. The appearance of any technical data or editorial material in this publication document does not constitute endorsement, warranty, or guaranty by ASHRAE of any product, service, process, procedure, design or the like and ASHRAE expressly disclaims such. Permission to republish or redistribute must be obtained from the MOS.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This addendum was released for public review from November 29, 2024 to January 13, 2025. This ISC has been prepared to address these comments where changes are required. In Section 3.3 for the SI version, the acronym AEER was proposed in the draft for a definition and acronyms, but the table used ACOP_C. This independent substantive change replaces AEER with ACOP_C in Section 3.2 and Section 3.3.

[Note to Reviewers: This public review draft makes proposed independent substantive changes to the previous public review draft. These changes are indicated in the text by underlining (for additions) and ~~strikethrough~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the previous draft are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed substantive changes.]

All comments should be submitted thru the ASHRAE online comment database.

[My Comments \(ashrae.org\)](https://www.ashrae.org/MyComments)

Comments should comply with the following;

- *Be marked as supportive or non-supportive*
- *Be specific to the text, section or table that is the subject of the comment*
- *Where possible proposed alternate language or requirements*
- *Provide supporting information if needed*
- *Comments should be submitted during the comment period*
- *Only text marked as underlined, or strikeout are open for comments.*

Do not use the following comment submittal approach;

- *Do not submit comments by email or other systems*
- *Comments should be on a single topic and do not submit multiple comments in one comment. If you have multiple comments submit multiple comments in the on-line system*
- *Attachments can be used for additional backup, but comments should be entered into the system*

Addendum ba to 90.1-2022

Modify the following definitions to section 3.2 (SI only)

applied cooling coefficient of performance (~~A~~EERACOP_C): A ratio of the cooling capacity in watts to the power input values in watts at standard rating conditions C3 in AHRI Standard 600, including system pump and cooling tower power, expressed in watts/watt

Modify the following abbreviations and acronyms to section 3.3 (SI only):

~~A~~EERACOP_C applied cooling coefficient of performance