



**BSR/ASHRAE Addendum z  
to ANSI/ASHRAE Standard 62.2-2025**

**Public Review Draft**

**Proposed Addendum z to  
Standard 62.2-2025, Ventilation and  
Acceptable Indoor Air Quality in  
Residential Buildings**

**First Public Review (August 2025)  
(Draft shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at [www.ashrae.org/standards-research--technology/public-review-drafts](http://www.ashrae.org/standards-research--technology/public-review-drafts) and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at [www.ashrae.org/bookstore](http://www.ashrae.org/bookstore) or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, [www.ashrae.org](http://www.ashrae.org).

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2025 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 180 Technology Parkway NW, Peachtree Corners, GA 30092. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: [standards.section@ashrae.org](mailto:standards.section@ashrae.org).

**ASHRAE, 180 Technology Parkway NW, Peachtree Corners, GA 30092**

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

## FOREWORD

*This proposed change clarifies the requirements in Section 5.1 Local Mechanical Exhaust. The standard used “provides local mechanical exhaust” instead of “provides exhaust” because someone might be confused over whether a whole-house exhaust system that is also used as a local exhaust system must exhaust from each room in the home (not necessary). Also, we specified “exhaust inlet” instead of “inlet” to remove any ambiguity around what type of inlet we’re referencing.*

*[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~striking through~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]*

## Addendum z to 62.2-2025

---

***Revise Section 5.1 as shown below.***

**5.1 Local Mechanical Exhaust.** ~~A~~ One or more local mechanical exhaust systems shall be designed and installed ~~in each to serve every~~ kitchen, bathroom, and toilet room. Where a single exhaust fan provides local mechanical exhaust to multiple rooms, there shall be an exhaust inlet in each room served. The system ~~and~~ shall be one of the following:

- a) a demand-controlled local mechanical exhaust system meeting the requirements of Section 5.2 or
- b) a continuous local mechanical exhaust system meeting the requirements of Section 5.3.