



**BSR/ASHRAE Addendum e
to ANSI/ASHRAE Standard 62.2-2025**

Public Review Draft

Proposed Addendum e to Standard 62.2-2025, Ventilation and Acceptable Indoor Air Quality in Residential Buildings

**First Public Review (2026)
(Draft shows Proposed Changes to Current Standard)**

This draft has been recommended for public review by the responsible project committee. To submit a comment on this proposed standard, go to the ASHRAE website at www.ashrae.org/standards-research--technology/public-review-drafts and access the online comment database. The draft is subject to modification until it is approved for publication by the Board of Directors and ANSI. Until this time, the current edition of the standard (as modified by any published addenda on the ASHRAE website) remains in effect. The current edition of any standard may be purchased from the ASHRAE Online Store at www.ashrae.org/bookstore or by calling 404-636-8400 or 1-800-727-4723 (for orders in the U.S. or Canada).

This standard is under continuous maintenance. To propose a change to the current standard, use the change submittal form available on the ASHRAE website, www.ashrae.org.

The appearance of any technical data or editorial material in this public review document does not constitute endorsement, warranty, or guaranty by ASHARE of any product, service, process, procedure, or design, and ASHRAE expressly disclaims such.

© 2024 ASHRAE. This draft is covered under ASHRAE copyright. Permission to reproduce or redistribute all or any part of this document must be obtained from the ASHRAE Manager of Standards, 180 Technology Parkway NW, Peachtree Corners, GA 30092. Phone: 404-636-8400, Ext. 1125. Fax: 404-321-5478. E-mail: standards.section@ashrae.org.

ASHRAE, 180 Technology Parkway NW, Peachtree Corners, GA 30092

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

This proposed addendum clarifies that normative Appendix D is intended as an alternative to Section 4. The additional sentence helps point to Appendix D from section 4.

As background, the top of Appendix D is as follows:

NORMATIVE APPENDIX D INDOOR AIR QUALITY PROCEDURE

The requirements of this appendix shall be applicable where selected by the designer as the compliance path for Section 4.

The *dwelling unit systems* shall meet the requirements for Sections D1 and D2. Where air-cleaning efficiencies or *contaminant* measurements are part of the design, the appropriate Sections D3 and D4 are also required.

D1. BIOEFFLUENT CONTROL SYSTEM

A *mechanical ventilation system* shall be installed and operated that meets either Section D1.1 or D1.2.

D1.1 Base Ventilation System. A *dwelling-unit mechanical ventilation system* in compliance with Sections 4.1 through 4.4 or Section 4.5 is required. It shall be operated at a rate not less than that specified in Section 4.1, calculated with a *floor area* of zero. Use of Section 4.1.4, “Ventilation-Rate Reduction for Particle Filtration,” is not permitted.

...

[Note to Reviewers: This addendum makes proposed changes to the current standard. These changes are indicated in the text by underlining (for additions) and ~~striketrough~~ (for deletions) except where the reviewer instructions specifically describe some other means of showing the changes. Only these changes to the current standard are open for review and comment at this time. Additional material is provided for context only and is not open for comment except as it relates to the proposed changes.]

Addendum e to 62.2-2025

4. DWELLING UNIT VENTILATION

Each *dwelling unit* shall be provided with a *mechanical ventilation system* that complies with the requirements of Sections 4.1 through 4.4, Section 4.5, or Section 4.6. Alternatively, the requirements of Appendix D, Indoor Air Quality Procedure, shall be met.